

Table of Contents

Chapter I

Introduction to Water Treatment

1.1 Water as a Limited Resource	2
1.2 Water Treatment	3
1.3 The Safe Drinking Water Act	5
1.4 Water Treatment Plants	8
1.4.1 Conventional Surface Water Treatment	8
1.4.2 Additional Treatment	10
1.5 Plant Operation	10
1.5.1 Daily Operating Procedures	11
1.5.1.1 At the Start of the Shift	12
1.5.1.2 During the Shift	14
1.5.1.3 At the End of the Shift	15
1.5.2 Regulation of Flows	15
1.5.2.1 Treatment Process Changes	18
1.5.3 Chemical Use and Handling	19
1.5.3.1 Storage and Supply	21
1.5.3.2 Safe Handling	22
1.5.3.3 First-Aid Procedures	23
1.5.4 Water Quality Monitoring	25
1.5.4.1 Turbidity Removal	25
1.5.4.2 Water Quality Complaints	26
1.5.5 Sludge Handling and Disposal	26
1.5.6 Process Instrumentation and Controls	28
1.5.6.1 Signal Transmission Methods	29
1.5.6.2 Control Methods	31
1.5.6.3 Computers	31
1.5.7 Emergency Conditions and Procedures	32
1.5.7.1 Treatment Process Failures	32
1.5.7.2 Process Equipment Failures	33
1.5.7.3 Power Failures	34
1.5.7.4 Fires	35

1.5.7.5 Natural Disasters	35
1.5.7.6 Communications	36
1.5.8 Operating Records and Reports	36
1.6 Plant Maintenance	38
1.6.1 Planning and Scheduling	38
1.6.2 Records Management	43
1.6.3 Spare Parts Management	43
1.6.4 Cost and Budget Control	44
1.6.5 Emergency Repair Procedures	44
1.6.6 Training Program	44
1.6.7 Security	45
1.7 Energy Conservation	45
1.7.1 Power Management	46
1.7.2 Power Cost Analysis	46
1.8 Supervision and Administration	47
1.9 Public Relations	49
1.10 Safety	49
1.11 Water Treatment Plant Operators	51
1.12 Math Assignment	53
1.13 Additional Resources	53
Chapter Review	55

Chapter 2

Source Water, Reservoir Management, and Intake Structures

2.1 Sources of Water	60
2.1.1 Ocean	60
2.1.2 Surface Water	60

X Table of Contents

2.1.2.1 Rivers and Streams	61
2.1.2.2 Lakes and Reservoirs	62
2.1.3 Groundwater	63
2.1.3.1 Wells	64
2.1.3.2 Springs	64
2.1.4 Reclaimed Water	64
2.2 Selection of a Water Source	65
2.2.1 Water Rights	66
2.2.2 Sanitary Survey	66
2.2.3 Contamination	68
2.2.3.1 Physical Characteristics	69
2.2.3.2 Chemical Characteristics	69
2.2.3.3 Biological Factors	70
2.2.3.4 Radiological Factors	71
2.3 Surface Reservoirs as Domestic Water Supplies	72
2.3.1 Factors Affecting Water Quality	72
2.3.1.1 Watershed Conditions	73
2.3.1.2 Thermal Stratification	75
2.3.1.3 Nutrients	77
2.3.1.4 Algal Blooms	79
2.3.1.5 Anaerobic Conditions	83
2.4 Reservoir Management Programs	84
2.4.1 Improvement and Maintenance of Water Quality	84
2.4.2 Reduction of Water Treatment Costs	85
2.4.3 Improvement and Maintenance of Fishery, Recreational, and Property Values	85
2.4.4 Removal of Trees and Brush from Areas to Be Flooded	86
2.4.5 Watershed Management	86
2.4.5.1 Wastewater	87
2.4.5.2 Fertilization	88
2.4.5.3 Industrial Discharges	88
2.4.5.4 Soil Grading and Farming Practices	89
2.4.5.5 Livestock Grazing	89
2.4.5.6 Pesticides and Herbicides	89
2.4.5.7 Wildfires	90
2.4.5.8 Land Use Control	90
2.4.5.9 Highway Stormwater Runoff	91
2.4.6 Algae Control by Chemical Methods	92
2.4.6.1 Chemicals Available	92
2.4.6.2 Methods of Copper Sulfate Application	93

2.4.6.3 Copper Sulfate Doses	94
2.4.6.4 Monitoring	101
2.4.6.5 Recordkeeping	101
2.4.6.6 Safety	101
2.4.7 Reaeration and Artificial Destratification	102
2.4.7.1 Methods of Reaeration	104
2.4.7.2 Destratification	104
2.4.7.3 Hypolimnetic Aeration or Oxygenation	105
2.4.8 Managing Frozen Reservoirs	106
2.4.8.1 Physical Effects of Ice Formation	106
2.4.8.2 Effects on Raw Water Quality	107
2.4.8.3 Recreational Use of Reservoir Ice Surfaces	108
2.4.9 Dam and Reservoir Maintenance	108
2.4.9.1 Dam Inspection and Maintenance	108
2.4.9.2 Reservoir Maintenance	108

2.5 Laboratory and Monitoring Programs 109

2.5.1 Procedures	110
2.5.2 Recordkeeping	111
2.5.3 Safety	112

2.6 Intake Structures 112

2.6.1 Types of Intake Structures	113
2.6.2 Types of Intake Gates	117
2.6.3 Intake Screens and Trash Racks	117
2.6.4 Operation and Maintenance Procedures	119
2.6.5 Records	120
2.6.6 Safety	120

2.7 Math Assignment 121

2.8 Additional Resources 121

Chapter Review 122

Chapter 3 Coagulation and Flocculation

3.1 Removing Particulates from Water 126

3.2 Coagulation 126

3.2.1 Coagulants	128
3.2.2 Basic Coagulant Chemistry	130
3.2.3 Effective Mixing	130

3.3 Flocculation	133
3.3.1 Process Performance	133
3.3.1.1 Detention Time	133
3.3.1.2 Types of Flocculators (Stirrers)	133
3.3.1.3 Flocculation Basins	134
3.4 Interaction with Other Treatment Processes	136
3.5 Process Control	136
3.6 Normal Operations	137
3.6.1 Process Actions	138
3.6.2 Process Operation	141
3.6.2.1 Detention Times	141
3.6.2.2 The Jar Test	145
3.6.2.3 Streaming Current Meters	155
3.6.2.4 Evaluation of Plant Performance	155
3.6.3 Chemical Usage for Small Plants	156
3.6.3.1 Calculating Amount of Chemical Required	156
3.6.3.2 Chemical Feeding	157
3.6.3.3 Preparation of Chemical Solutions	158
3.6.4 Recordkeeping	162
3.6.5 Safety	163
3.6.6 Communications	164
3.7 Abnormal Conditions	164
3.7.1 Process Actions	164
3.7.2 Recordkeeping	166
3.7.3 Communications	166
3.8 Startup and Shutdown Procedures	166
3.8.1 Startup Procedure	167
3.8.2 Shutdown Procedure	167
3.8.3 Recordkeeping	168
3.8.4 Safety	168
3.9 Laboratory Tests	169
3.9.1 Sampling Procedures	169
3.9.2 Sample Analysis	170
3.9.3 Safety	170
3.9.4 Recordkeeping	170

3.10 Equipment Operation and Maintenance	170
3.10.1 Chemical Feeders	171
3.10.2 Calibration Method	173
3.10.3 Preventive Maintenance Procedures	177
3.10.4 Safety	178
3.11 Enhanced Coagulation	179
3.11.1 Chemical Reactions	180
3.11.2 Process Control	180
3.12 Ballasted Flocculation	183
3.12.1 Process Stages	184
3.12.2 Startup	185
3.12.3 Microsand Management	186
3.12.3.1 Microsand Concentration Monitoring	186
3.12.3.2 Microsand Addition	189
3.12.4 Hydrocyclone Performance	190
3.12.5 Process Performance Monitoring	193
3.12.6 Process Optimization	193
3.12.7 Troubleshooting Procedures	194
3.12.8 Intermittent Use	195
3.12.8.1 Short-Term Standby Mode (Wet Storage)	195
3.12.8.2 Long-Term Shutdown and Freeze Protection	196
3.12.9 Equipment Maintenance	196
3.12.9.1 Tube Settler Modules	197
3.12.9.2 Mixers	197
3.12.9.3 Scrapers	198
3.12.9.4 Microsand Recirculation Pumps	198
3.12.9.5 Hydrocyclones	198
3.13 Math Assignment	199
3.14 Additional Resources	199
Chapter Review	200
Chapter 4	
Sedimentation	
4.1 Presedimentation	204
4.2 Process Performance	204

4.2.1 Nature of Particulate Impurities 206

4.2.2 Water Temperature 207

4.2.3 Currents 207

4.2.4 Particle Interactions 207

4.3 Sedimentation Basins 208

4.3.1 Basin Types 212

4.3.1.1 Rectangular Basins 212

4.3.1.2 Double-Deck Basins 213

4.3.1.3 Circular and Square Basins 213

4.3.1.4 High-Rate Settlers 213

4.3.1.5 Solids-Contact Units 215

4.4 Design and Operational Guidelines 219

4.4.1 Basin Layout 219

4.4.2 Detention Time 219

4.4.3 Surface Loading 223

4.4.4 Effective Water Depth 225

4.4.5 Mean Flow Velocity 225

4.4.6 Weir Loading Rate 226

4.5 Solids-Contact Clarification 227

4.5.1 Operational Control 231

4.5.2 Maintenance 234

4.5.3 Calculations 234

4.6 Sludge Handling 239

4.6.1 Sludge Removal Systems 240

4.6.2 Sludge Removal Frequency 242

4.7 Interaction with other Treatment Processes 243

4.8 Normal Operations 244

4.8.1 Process Control 245

4.8.2 Process Actions 245

4.8.3 Recordkeeping 246

4.9 Abnormal Operations 248

4.9.1 Process Actions 248

4.10 Startup and Shutdown Procedures 250

4.10.1 Startup Procedure 250

4.10.2 Shutdown Procedure 251

4.11 Laboratory Tests 251

4.11.1 Sampling Procedures 251

4.11.2 Sample Analysis 252

4.12 Equipment Operation and Maintenance 252

4.12.1 Corrosion Control 253

4.12.2 Preventive Maintenance Procedures 253

4.12.3 Safety 254

4.13 Math Assignment 255

4.14 Additional Resources 255

Chapter Review 256

Chapter 5 Filtration

5.1 Filtration Mechanisms 260

5.2 Types of Filters 262

5.2.1 Gravity Filtration 262

5.2.2 Pressure Filtration 263

5.2.3 Diatomaceous Earth Filtration 264

5.2.4 Slow Sand Filtration 264

5.3 Process Performance Considerations 265

5.3.1 Filter Media 265

5.3.2 Operational Criteria 267

5.3.2.1 Filter Layout 267

5.3.2.2 Filter Production and Filtration Rate 267

5.3.2.3 Filtration Efficiency 267

5.3.3 Filter Operation 270

5.3.3.1 Filtration Mode 270

5.3.3.2 Backwashing 270

5.3.3.3 Surface Wash 272

5.3.4 Filter Control Systems 273

5.4 Activated Carbon Filters 274

5.5 Interaction with Other Treatment Processes 275

5.5.1 Pretreatment Processes 275

5.5.2 Inline Filtration 276

5.5.3 Conventional Filtration (Treatment) 276

5.5.4 Direct Filtration 276

5.6 Process Control 278

5.7 Operating Procedures Associated with Normal Process Conditions 278

5.7.1 Process Actions 280

5.7.2 Mudball Evaluation Procedure 283

5.7.3 Process Calculations 286

5.7.3.1 Filter Efficiency 286

5.7.3.2 Filtration Rate 287

5.7.3.3 Backwash Rate 291

5.7.4 Recordkeeping 294

5.7.5 Filter Monitoring Instrumentation 294

5.8 Operating Procedures Associated with Abnormal Process Conditions 296

5.8.1 Process Actions 296

5.8.2 Air Binding 299

5.8.3 Excessive Head Loss 299

5.9 Startup and Shutdown Procedures 300

5.9.1 Implementation of Startup/Shutdown Procedures 300

5.9.1.1 Filter Checkout Procedures 301

5.9.1.2 Backwash Procedures 301

5.9.1.3 Filter Startup Procedures 302

5.9.1.4 Filter Shutdown Procedures 303

5.10 Process and Support Equipment Operation and Maintenance 303

5.10.1 Equipment Operation 304

5.10.2 Preventive Maintenance Procedures 304

5.10.3 Safety Considerations 305

5.11 Drinking Water Regulations 305

5.11.1 Safe Drinking Water Act (SDWA) 305

5.11.2 Surface Water Treatment Rule (SWTR) 307

5.11.3 Turbidity Requirements 308

5.12 Particle Counters 309

5.12.1 Particle Counting to Monitor Filter Performance 310

5.12.1.1 Filter Ripening 310

5.12.1.2 Filter Flow Rate 310

5.12.1.3 Filter Run Time 310

5.12.1.4 Filter Media Selection 311

5.12.1.5 Polymer Application 311

5.12.1.6 Other Uses of Particle Counters 311

5.12.2 How Particle Counters Work 311

5.12.3 Grab vs. In-Process Particle Counters 313

5.12.3.1 Grab Samples 313

5.12.3.2 In-Process Measurements 314

5.12.4 Particle Counters Compared to Turbidity Meters 315

5.12.5 Operation and Maintenance 316

5.12.5.1 Sampling 317

5.12.5.2 Flow Control 317

5.12.5.3 Sample Tubing 317

5.12.5.4 Bubbles 317

5.12.5.5 Initial Startup 319

5.12.5.6 Overconcentration 319

5.12.5.7 Troubleshooting 319

5.12.5.8 Quality Assurance/Quality Control 319

5.13 Math Assignment 320

5.14 Additional Resources 320

Chapter Review 321

Chapter 6 Disinfection

6.1 Drinking Water Safety 326

6.1.1 Safe Drinking Water Laws 326

6.2 Factors Influencing Disinfection 329

6.2.1 pH 329

6.2.2 Temperature 329

6.2.3 Turbidity 329

6.2.3.1 Organic Matter 330

6.2.3.2 Inorganic Matter 330

6.2.4 Reducing Agents 330

6.2.5 Microorganisms 330

6.2.5.1 Removal Processes 330

6.3 Disinfection Process 331

6.3.1 Physical Means of Disinfection 331

6.3.2 Chemical Disinfectants (Other Than Chlorine) 332

- 6.3.3 Chlorine 333
 - 6.3.3.1 Chlorine Disinfection Action 333
 - 6.3.3.2 Reaction with Water 334
 - 6.3.3.3 Reaction with Impurities in Water 335
- 6.3.4 Hypochlorite 336
 - 6.3.4.1 Reactions with Water 336
 - 6.3.4.2 Differences Between Chlorine Gas and Hypochlorite Compound Reactions 337
 - 6.3.4.3 Onsite Chlorine Generation 337
- 6.3.5 Chlorine Dioxide 337
 - 6.3.5.1 Reaction in Water 338
 - 6.3.5.2 Reactions with Impurities in Water 338
- 6.3.6 Breakpoint Chlorination 338
- 6.3.7 Chloramination 340
 - 6.3.7.1 Methods for Producing Chloramines 340
 - 6.3.7.2 Chlorine-to-Ammonia-Nitrogen Ratios 341
 - 6.3.7.3 Special Water Users 342
 - 6.3.7.4 Blending Chloraminated Waters 342
 - 6.3.7.5 Chloramine Residuals 342
- 6.3.8 Nitrification 342
 - 6.3.8.1 Nitrification Prevention and Control 343
- 6.3.9 Chlorine Residual Testing 344
 - 6.3.9.1 Chlorine Residual Curve 345
 - 6.3.9.2 Critical Factors 346
- 6.3.10 CT Values 346
- 6.3.11 Process Calculations 347

6.4 Points of Chlorine Application 349

- 6.4.1 Prechlorination 349
- 6.4.2 Postchlorination 349
- 6.4.3 Rechlorination 349
- 6.4.4 Wells 349
- 6.4.5 Mains 351
- 6.4.6 Tanks and Reservoirs 351

6.5 Operation of Chlorination Equipment 351

- 6.5.1 Hypochlorinators 351
- 6.5.2 Chlorinators 353
 - 6.5.2.1 Chlorinator Flow Path 356
 - 6.5.2.2 Chlorinator Parts and Their Purpose 358
- 6.5.3 Chlorine Containers 359
 - 6.5.3.1 Plastic 359
 - 6.5.3.2 Steel Cylinders 360
 - 6.5.3.3 Ton Tanks 361

- 6.5.4 Protect Yourself from Chlorine 362
- 6.5.5 Removing Chlorine from Containers 362
 - 6.5.5.1 Connections 362
 - 6.5.5.2 Valves 363
 - 6.5.5.3 Ton Tanks 363
- 6.5.6 Performance of Chlorination Units 363
 - 6.5.6.1 Hypochlorinators 364
 - 6.5.6.2 Chlorinators 368
- 6.5.7 Normal and Abnormal Operation 373
 - 6.5.7.1 Container Storage Area 373
 - 6.5.7.2 Evaporators 374
 - 6.5.7.3 Chlorinators, Including Injectors 376
 - 6.5.7.4 Summary, Daily Operation 381
 - 6.5.7.5 Laboratory Tests 383
- 6.5.8 Troubleshooting Gas Chlorinator Systems 384
- 6.5.9 Disinfection Troubleshooting 385
- 6.5.10 Chlorination System Failure 385

6.6 Maintenance 385

- 6.6.1 Chlorine Leaks 385
- 6.6.2 Installation 389

6.7 Chlorine Dioxide Facilities 391

- 6.7.1 Safe Handling of Chemicals 393
- 6.7.2 Operation 393
 - 6.7.2.1 Prestart Procedures 393
 - 6.7.2.2 Startup 395
 - 6.7.2.3 Shutdown 395
- 6.7.3 Maintenance 396
- 6.7.4 Troubleshooting 397

6.8 Measurement of Chlorine Residual 399

- 6.8.1 Methods of Measuring Chlorine Residual 399
- 6.8.2 ORP Probes 400

6.9 Chlorine Safety Program 401

- 6.9.1 Chlorine Hazards 401
- 6.9.2 Why Chlorine Must Be Handled with Care 402
- 6.9.3 Protect Yourself from Chlorine 402
- 6.9.4 Hypochlorite Safety 405
- 6.9.5 Chlorine Dioxide Safety 405
- 6.9.6 Operator Safety Training 405
- 6.9.7 CHEMTREC 406

6.10 Ultraviolet (UV) Systems 406

- 6.10.1 UV Lamp Types 407
- 6.10.2 UV System Types 407
- 6.10.3 Safety 408
- 6.10.4 Operation 409
 - 6.10.4.1 UV Light Intensity Effectiveness 409
 - 6.10.4.2 Minimum UV Dose Management 409
 - 6.10.4.3 Routine Operations Tasks 411
 - 6.10.4.4 Wiping System 412
 - 6.10.4.5 Equipment Shutdown/Startup Preliminary Steps 412
 - 6.10.4.6 Shutdown Sequence 413
 - 6.10.4.7 Cleaning the Tank 413
 - 6.10.4.8 Startup Sequence 413
 - 6.10.4.9 Monitoring Lamp Output Intensity 413
 - 6.10.4.10 Monitoring Influent and Effluent Characteristics 414
- 6.10.5 Emergency Alarms 414
- 6.10.6 Maintenance 415
 - 6.10.6.1 Quartz Sleeve Cleaning 415
 - 6.10.6.2 Lamp Maintenance 416
- 6.10.7 Troubleshooting 417
 - 6.10.7.1 System Hydraulics 417
 - 6.10.7.2 Biofilms on UV Channel Walls and Equipment 417
 - 6.10.7.3 Particles Shielding Bacteria 417

6.11 Ozone Systems 417

- 6.11.1 Equipment 418
- 6.11.2 Gas Preparation 418
- 6.11.3 Electrical Supply Unit 419
- 6.11.4 Ozone Generator 419
- 6.11.5 Ozone Contactor 420
- 6.11.6 Ozone Residuals 420
- 6.11.7 Safety 421
- 6.11.8 Maintenance 421
- 6.11.9 Applications of Ozone 421
- 6.11.10 Advantages and Limitations of Ozone 422

6.12 Mixed-Oxidants (Miox) Systems 423**6.13 Typical Chlorination Math Problems 424**

- 6.13.1 Chlorinators 424
- 6.13.2 Hypochlorinators 428

6.14 Math Assignment 431**6.15 Additional Resources 432****Chapter Review 433****Chapter 7****Corrosion Control****7.1 Adverse Effects of Corrosion 438****7.2 Corrosion Process 438**

- 7.2.1 Electrochemical Corrosion: The Galvanic Cell 438

7.3 Factors Influencing Corrosion 443

- 7.3.1 Physical Factors 443
 - 7.3.1.1 System Construction 443
 - 7.3.1.2 System Pressure 444
 - 7.3.1.3 Soil Moisture 444
 - 7.3.1.4 Stray Electric Current 444
 - 7.3.1.5 Temperature 445
 - 7.3.1.6 Flow Velocity 445
- 7.3.2 Chemical Factors 446
 - 7.3.2.1 Alkalinity 446
 - 7.3.2.2 pH 447
 - 7.3.2.3 Dissolved Oxygen 447
 - 7.3.2.4 Dissolved Solids 447
 - 7.3.2.5 Hardness 447
 - 7.3.2.6 Chloride and Sulfate 448
 - 7.3.2.7 Phosphate and Silicate 448
 - 7.3.2.8 Trace Metals 448
- 7.3.3 Biological Factors 449
 - 7.3.3.1 Iron Bacteria 449
 - 7.3.3.2 Sulfate-Reducing Bacteria 449
- 7.3.4 Oxygen Concentration Cell 450

7.4 How to Determine if Corrosion Problems Exist 452

- 7.4.1 Examine Materials Removed from Distribution System 453
- 7.4.2 Flow Tests 453
- 7.4.3 Chemical Tests on Water 454
 - 7.4.3.1 Dissolved Oxygen 454
 - 7.4.3.2 Toxic Heavy Metals 455
 - 7.4.3.3 Calcium Carbonate Saturation 456
- 7.4.4 Complaints 459

7.5 Methods of Controlling Corrosion 459

- 7.5.1 Selection of Corrosion Control Chemicals 459
- 7.5.2 Determination of Chemical Dose 463
- 7.5.3 Determination of Chemical Feeder Setting 464
- 7.5.4 Zinc, Silica, and Polyphosphate Compounds 466
- 7.5.5 Cathodic Protection 466
 - 7.5.5.1 How the Protection System Works 466
 - 7.5.5.2 Equipment 467
 - 7.5.5.3 Protection of Flocculators, Clarifiers, and Filters 467
 - 7.5.5.4 Maintenance 468
- 7.5.6 Removal of Oxygen 469
- 7.5.7 External Corrosion 469
 - 7.5.7.1 Soil Corrosion 469
 - 7.5.7.2 Corrosion of Steel Embedded in Concrete 470
 - 7.5.7.3 Stray Electric Currents 470

7.6 Troubleshooting 472

- 7.6.1 Internal Pipe Corrosion 472
- 7.6.2 External Pipe Corrosion 472

7.7 The Lead and Copper Rule 473

- 7.7.1 Health Concerns 473
- 7.7.2 Regulations 473
- 7.7.3 Monitoring Requirements 475
 - 7.7.3.1 Monitoring Frequency 475
 - 7.7.3.2 Sampling Procedure 475
 - 7.7.3.3 Maximum Contaminant Level Goals (MCLGs) 476
 - 7.7.3.4 Other Water Quality Monitoring 477
 - 7.7.3.5 Analytical Methods and Certification Requirements 477
- 7.7.4 Treatment Requirements 478
 - 7.7.4.1 Corrosion Treatment Studies 478
 - 7.7.4.2 Source Water Treatment 478
 - 7.7.4.3 Lead Service Line Replacement 479
 - 7.7.4.4 Treatment for Control of Lead and Copper 479
- 7.7.5 Public Education and Reporting Requirements 480
 - 7.7.5.1 Public Education 480
 - 7.7.5.2 Reporting and Recordkeeping Requirements 481

7.8 Math Assignment 482

7.9 Additional Resources 482

Chapter Review 483

**Chapter 8
Taste and Odor Control**

8.1 Effects of Taste and Odor Problems 488

8.2 Causes of Tastes and Odors 489

- 8.2.1 Common Taste and Odor Compounds 489
- 8.2.2 Natural Causes 490
 - 8.2.2.1 Biological Growth in Source Waters 490
 - 8.2.2.2 Environmental Conditions 492
- 8.2.3 Human Causes 495
 - 8.2.3.1 Municipal Wastewaters 495
 - 8.2.3.2 Industrial Wastes 495
 - 8.2.3.3 Chemical Spills 496
 - 8.2.3.4 Urban Runoff 496
 - 8.2.3.5 Agricultural Wastes 496
 - 8.2.3.6 Treatment Plant and Distribution System Conditions 497
 - 8.2.3.7 Household Plumbing 498

8.3 Locating Taste and Odor Sources 498

- 8.3.1 Raw Water Sources 499
- 8.3.2 Treatment Plant 500
- 8.3.3 Distribution System 500

8.4 Taste and Odor Prevention and Monitoring 502

- 8.4.1 Raw Water Management 502
- 8.4.2 Plant Maintenance 503
- 8.4.3 Distribution System Maintenance 503

8.5 Taste and Odor Treatment 504

- 8.5.1 Improved Coagulation/Flocculation/Sedimentation 505
- 8.5.2 Aeration Processes and Systems 506
 - 8.5.2.1 Air Blowers 506
 - 8.5.2.2 Cascades and Spray Aerators 507
 - 8.5.2.3 Air Stripping 508
- 8.5.3 Oxidative Processes 509
 - 8.5.3.1 Chlorine 509
 - 8.5.3.2 Potassium Permanganate 510

- 8.5.3.3 Ozone 512
- 8.5.3.4 Chlorine Dioxide 513
- 8.5.4 Adsorption Processes 514
 - 8.5.4.1 Powdered Activated Carbon 514
 - 8.5.4.2 Granular Activated Carbon 522

8.6 Identifying Taste and Odor Problems 523

8.7 Developing a Taste and Odor Control Strategy 525

8.8 Math Assignment 528

8.9 Additional Resources 528

Chapter Review 529

Chapter 9

Laboratory Procedures

9.1 Basic Laboratory Concepts, Equipment, and Techniques 534

- 9.1.1 Laboratory Units: The Metric System 534
- 9.1.2 Chemical Names and Formulas 536

9.2 Laboratory Equipment and Techniques 538

- 9.2.1 Water Laboratory Equipment 538
- 9.2.2 Using Laboratory Glassware 542
 - 9.2.2.1 Reading Volumes 542
 - 9.2.2.2 Using Pipets 543
- 9.2.3 Chemical Solutions 545
 - 9.2.3.1 Mass Concentration 545
 - 9.2.3.2 Molar Concentration 546
 - 9.2.3.3 Normality 547
- 9.2.4 Data Recording and Recordkeeping 548
- 9.2.5 Laboratory Quality Control 549

9.3 Laboratory Safety 550

- 9.3.1 Laboratory Hazards 550
- 9.3.2 Personal Safety and Hygiene 551
- 9.3.3 Preventing Laboratory Accidents 552
 - 9.3.3.1 Chemical Storage 552
 - 9.3.3.2 Moving Chemicals 552
 - 9.3.3.3 Proper Laboratory Techniques 553
 - 9.3.3.4 Accident Prevention 554

9.4 Water Quality Tests 557

- 9.4.1 Instrument-Based Tests 557
 - 9.4.1.1 Temperature 557
 - 9.4.1.2 pH 559
 - 9.4.1.3 Turbidity 561
- 9.4.2 Titration-Based Tests 564
 - 9.4.2.1 General Titration Procedure 564
 - 9.4.2.2 Alkalinity 565
 - 9.4.2.3 Hardness 570
 - 9.4.2.4 Chlorine Residual 572
- 9.4.3 Tests for Plant Processes 579
 - 9.4.3.1 Jar Test for Coagulation/Flocculation 579
 - 9.4.3.2 Chlorine Demand 584
- 9.4.4 Biological Tests 588
 - 9.4.4.1 Test Methods Overview 589
 - 9.4.4.2 What is Tested 592
 - 9.4.4.3 General Materials Required for Microbial Testing 592
 - 9.4.4.4 Procedures for Testing Total Coliform Bacteria 594
 - 9.4.4.5 Additional Test Methods 618

9.5 Sampling 619

- 9.5.1 Representative Sampling 619
 - 9.5.1.1 Source Water Sampling 619
 - 9.5.1.2 In-Plant Sampling 620
 - 9.5.1.3 Distribution System Sampling 620
- 9.5.2 Types of Samples 623
 - 9.5.2.1 Grab Samples 623
 - 9.5.2.2 Composite Samples 623
- 9.5.3 Sampling Devices 624
- 9.5.4 Sampling Techniques 625
 - 9.5.4.1 Surface Sampling 625
 - 9.5.4.2 Depth Sampling 625
 - 9.5.4.3 Water Tap Sampling 626
 - 9.5.4.4 First-Draw Samples 627
- 9.5.5 Sampling Containers and Preservation of Samples 627
 - 9.5.5.1 Chain-of-Custody Samples 627
- 9.5.6 Reporting 627

9.6 Math Assignment 629

9.7 Additional Resources 629

Chapter Review 630

Appendix A

Introduction to Basic Math for Operators

Introduction	634
Basic Concepts (Sections A.1–A.4)	635
A.1 Numbers and Operations	635
A.1.1 Addition	635
A.1.2 Subtraction	635
A.1.3 Multiplication	636
A.1.4 Division	636
A.2 Order of Operations	636
A.2.1 More on Exponents	640
A.3 Basic Algebra (Solving Equations)	640
A.4 Percentages	643
Intermediate Concepts (Sections A.5–A.6)	646
A.5 Units	646
A.5.1 Distance or Length	646
A.5.2 Area	647
A.5.2.1 Surface Area of a Rectangle	647
A.5.2.2 Surface Area of a Triangle	648
A.5.2.3 Surface Area of a Trapezoid	649
A.5.2.4 Surface Area of a Circle	649
A.5.2.5 Surface Area of a Cylinder	650
A.5.2.6 Surface Area of a Cone	651
A.5.2.7 Surface Area of a Sphere	652
A.5.3 Volume	652
A.5.3.1 Cube	653
A.5.3.2 Rectangular Prism	653
A.5.3.3 Triangular Prism	654
A.5.3.4 Cylinder	654
A.5.3.5 Cone	654
A.5.3.6 Sphere	655
A.5.4 Mass and Weight	655
A.5.5 Density, Specific Weight, and Specific Gravity	656
A.5.6 Concentration	656

A.5.7 Velocity and Flow Rate	658
A.5.8 Force and Pressure	660
A.5.9 Work, Head, and Power	665

A.6 Metric System 668

A.6.1 SI Base Units	668
A.6.2 Measures of Length	670
A.6.3 Measures of Capacity or Volume	670
A.6.4 Measures of Weight	670
A.6.5 Temperature	671

Advanced Concepts (Sections A.7–A.8) 672

A.7 Pumps 672

A.7.1 Pressure	672
A.7.2 Work	673
A.7.3 Power	674
A.7.4 Horsepower	674
A.7.5 Head	678
A.7.6 Pump Characteristics	680
A.7.7 Evaluation of Pump Performance	682
A.7.7.1 Capacity	682
A.7.7.2 Efficiency	683
A.7.8 Pump Speed-Performance Relationships	686
A.7.9 Friction or Energy Losses	687

A.8 Analysis and Presentation of Data 691

A.8.1 Causes of Variations in Results	691
A.8.1.1 Water or Material Being Examined	692
A.8.1.2 Sampling	692
A.8.1.3 Testing	692
A.8.2 Controlling Variation	692
A.8.2.1 Reading Charts	694
A.8.3 Describing Data or Results	694
A.8.3.1 Graphs and Charts	695
A.8.3.2 Numerical Representation of Data	700
A.8.4 Moving Averages	707
A.8.5 More Applications of Graphs	709
A.8.5.1 Volume of Sludge in a Digester	709
A.8.5.2 Tracking BOD Loading	712

A.8.6 Regression Analysis (Prediction Equations, Trends, and Correlations) 714**A.8.6.1 Correlations 719****A.9 Typical Water Treatment Plant Problems (English System) 720****A.9.1 Plant Operation 720****A.9.2 Flows 721****A.9.3 Chemical Doses 721****A.9.4 Reservoir Management and Intake Structures 724****A.9.5 Coagulation and Flocculation 726****A.9.6 Sedimentation 727****A.9.7 Filtration 728****A.9.8 Disinfection 732****A.9.9 Corrosion Control 734****A.9.10 Laboratory Procedures 735****A.10 Typical Water Treatment Plant Problems (Metric System) 736****A.10.1 Plant Operation 736****A.10.2 Flows 737****A.10.3 Chemical Doses 737****A.10.4 Reservoir Management and Intake Structures 740****A.10.5 Coagulation and Flocculation 742****A.10.6 Sedimentation 742****A.10.7 Filtration 744****A.10.8 Disinfection 749****A.10.9 Corrosion Control 751****A.10.10 Laboratory Procedures 751****Answer Key 755****Glossary 759****Index 793**

A

- Abnormal conditions
 - chlorination, 351, 368, 373, 379–380
 - coagulation, 164, 165
 - filtration, 296
 - flocculation, 164, 165
 - sedimentation, 248
- Absorption, 260
- Accident prevention, 552–556
- Accident reports, 37
- Accidents, laboratory, 552
- Acidic, defined, 559
- Acid rain, 2, 72
- Acids, used in laboratories, 551
- Acid titration curve, 566
- Acquisition, water rights, 66
- Activated carbon, 20, 263, 274–275, 510, 514–523, 527
- Additional resources
 - algae control, 96, 101
 - aquatic weed control, 101
 - chlorination, 432
 - coagulation, 199
 - corrosion control, 457, 464, 482
 - disinfection, 432
 - filtration, 320
 - flocculation, 199
 - hardness in water, 570
 - intake structures, 121
 - laboratory procedures, 534, 556, 559, 560, 564, 570, 578, 588, 607, 612, 614
 - laboratory safety, 556
 - lake destratification, 103
 - microbiological test methods, 618
 - microscopic organisms, controlling, 101
 - operation, 53
 - reservoirs, 121
 - safe drinking water, 8
 - sampling, 627
 - sedimentation, 255
 - source water, 121
 - standard methods, laboratory, 82
 - taste and odor control, 528
 - water quality, 26
 - water sources, 71
 - water utilities, 71
- Administration
 - coagulation, 162
 - filtration, 294
 - flocculation, 162
 - operator duties, 47
 - sedimentation, 246
- Adsorbate, 514
- Adsorbent, 514
- Adsorption, 96, 230, 260, 265, 514, 522
- Adverse effects, corrosion, 438
- Aeration, 105, 506–508
- Aggressive Index (AI), 459
- Aging tank, 159
- Agricultural runoff, 3, 60–61, 67, 73, 496
- AI. *See* Aggressive Index (AI)
- Air binding, filters, 299
- Air blowers, 506
- Air conditioning, 45
- Air gap, 369
- Air stripping, 508
- Algae
 - additional resources, 82
 - blue-green, 80, 96, 103
 - chemical control, 19
 - chlorine demand, 82
 - control in reservoirs
 - additional resources, 97, 101
 - aesthetics, 92
 - application of chemicals, 92, 93
 - bluestone algicide, 92
 - chemical dosage, 94
 - chemicals available, 92
 - chemical use and handling, 19
 - copper sulfate, 92, 93
 - formulas, 97
 - monitoring, 101
 - permits, 92
 - purpose, 92
 - recordkeeping, 101
 - reservoirs, 92
 - safety, 92, 101
 - species, 96
 - dissolved oxygen, 82
 - filtration, 284, 296, 297, 304
 - identification, 82
 - monitoring, 101
 - nutrients, 62
 - organic loading, 82
 - pH, 81
 - photosynthesis, 81
 - reservoirs, 92
 - respiration, 81, 493
 - solids-contact units, problems, 228
 - tastes and odors, 79
- Algal blooms, 62, 67, 75, 79–82, 86, 92–102, 105, 108, 111, 118, 491, 492, 505, 527
- Aliphatic hydroxy acids, 96
- Aliquot, 608
- Alkalinity
 - and buffering, 565
 - coagulation, 130
 - conditions, 568
 - corrosion control, 446
 - methyl orange, 94
 - monitoring, 582
 - procedure, 567
 - solids-contact units, 231
 - test, 565–570
- Alum, 20, 128, 129, 147, 153, 163, 179
 - feeder, 34
 - sludges, 239
- Aluminum sulfate, 20, 128, 147, 153, 163, 179
- Ambient temperature, 390
- Amendments to the Safe Drinking Water Act (SDWA), 306
- Ammonia, 335, 337, 339, 342, 386, 391
- Ammonia-oxidizing bacteria (AOB), 342
- Ammonia, test for leaks, 370, 386
- Ammonium hydroxide, 20
- Ammonium sulfate, 20
- Ampere, 444
- Amperometric titration method, 399, 574
- Anaerobic, 77, 83, 102, 451
- Analog, 692
- Anhydrous ammonia, 20
- Anionic polymer, 20, 128
- Annular space, 451, 452
- Anode, 439
- Anthracite coal, 263, 265, 267, 269
- AOB. *See* Ammonia-oxidizing bacteria (AOB)
- Apparent color, 180
- Application of chemicals, reservoirs, 92, 94
- Aquatic plants, 78
- Aquatic weed control, additional resources, 101
- Aquifer, groundwater, 63
- Arsenic, 5
- Artesian wells, 61, 63
- Artificial respiration, 24

- Asbestos-cement pipe, 466
Aseptic, 611
Autoclave, 542, 593
Automatic sampling, 624
Available chlorine residual, 334, 338
- B**
- Backflow prevention, 501
Backwashing filters, 269, 270, 286, 292, 301–302
Bacteria
 defined, 623
 detection methods, 589
 quantity affect on sample, 596
 types of counts, 589
Bacterial cells, 331
Bacterial cultures, 589
Bacteria, pathogenic, 26, 326
Bacteriologic safety indicator, 588
Baffles
 coagulation, 135, 136
 flocculation, 135, 136
 mixing, 130–136
 sedimentation, 207, 209
Ballasted flocculation
 flocculation basin, 184
 hydrocyclones, 185, 190
 injection tank, 185
 intermittent use, 195
 maintenance, 196
 microsand, 186
 optimization, 193
 performance, 193
 rapid mix tank, 184
 sedimentation basin, 185
 troubleshooting, 195
Barium, 5
Bases (caustics), used in laboratories, 551
Basins
 flocculation, 134–135
 sedimentation, 208–219
Batch mixture, polymer, 159
Baylis surface wash system, 272
Biochemical oxygen demand (BOD), 27, 77, 454
Biological growths, 490, 500, 508, 527
Biological tests, 588–618
Biological, water quality, 70
Bitter tastes, 332, 455
Blanket (sludge) sounder, 242
Blanks, 593
Blenders, pumped, 132
Blowers, 506
Blue-green algae, 80, 96, 103
Bluestone algicide, 92
BOD. *See* Biochemical oxygen demand (BOD)
Boils, filters, 283, 284, 296, 297, 298
Bottled water, 488
Breakpoint chlorination, 338, 381, 586
Breakthrough, filters, 266, 270, 282, 297, 298, 315
Brilliant Green Bile (BGB) Broth, 590, 594
Bromine, 332
Bruises, injury, 550
Buddy system, safety, 50, 305
Budget, maintenance, 38
Buffer, 130, 337, 446
Buffered dilution water, 593
Buffer solution, 561
Bumping a filter, 283
Burns
 first aid, 23
 laboratory, 550, 555
Butterfly valves, 117
Byproducts, disinfection, 7, 179
- C**
- Cadmium, 5, 456
Calcium carbonate, 447, 454, 456, 459–465
 equivalent, 448, 565, 569, 570
Calcium carbonate precipitation potential (CCPP), 454, 456
Calcium hydroxide, 20
Calcium hypochlorite, 20, 336
Calcium oxide, 20
Calibration, instrument, 541
Capacitors, 46
Carcinogen, 331, 573
Carcinogen chlororganic compounds, 573
Cardiopulmonary resuscitation (CPR), 24
Cascade aerator, 507
Cathode, 440
Cathode film protection, 442
Cathode ray tube displays, 30
Cathodic protection
 chlorination equipment, 375
 corrosion control, 113, 118, 443, 466–472
 intake-outlet structures, 115, 117
 sedimentation basins, 233
 solids-contact units, 233
Cationic polymer, 20, 129, 147
 pretreatment process aids, 275
Cations, 439
Cattails, 109
Caustics, 23, 551
Caustic soda, 20, 461, 462, 551
CCPP. *See* Calcium carbonate precipitation potential (CCPP)
Certification, operator, 44, 47, 52
Chain-of-custody sample protocol, 627
Charge chemistry, 180
Checklist, plant inspection, 12, 13
Chelated, 92
Chemical disinfectants, 332
Chemical dosage
 algae control, 96
 coagulation, 156–164
 reservoirs, 96
 solids-contact units, 227–239
Chemical feeders
 adjustment, 172
 calibration, 173
 coagulation, 151
 gravimetric, 172
 volumetric, 172
Chemical labeling, laboratory, 553
Chemical mixing, 129
Chemical names, 536–538
Chemical solution, 158, 545–549
 tank, 351
Chemical spills, 51, 496
Chemical storage
 and movement, 552
 and supply, 21
Chemical tests, corrosion, 454–459
Chemical use and handling
 algae control, 19, 20
 calculations, 21
 characteristics, 20
 chlorine, 20, 21, 23
 clarification, 19
 coagulation, 18, 20
 corrosion control, 19, 20, 462
 disinfection, 19, 20
 first aid, 23
 fluoridation, 19, 20
 recordkeeping, 36–38
 safety, 22, 23, 50
 softening, 19, 20
 storage, 21, 552
 taste and odor control, 19, 20
 turbidity reduction, 19
 types, 19, 20
Chemical, water quality, 66–68
Chemistry
 coagulation-flocculation, 129, 145
 corrosion, 438, 441
 disinfection, 331–334
 enhanced coagulation, 179
CHEMTREC, 406
Chloramination
 blending, 342
 chlorine to ammonia-nitrogen ratios, 341
 contact time, 346
 critical factors, 346
 how to produce chloramines, 341
 nitrification, 341, 342
 postammoniation, 340
 preammoniation, 340
 prechlorination, 341
 residuals, 341
 special water users, 342
 use, 340
Chloramines, 336, 338–344
Chloride, 7
Chlorinated hydrocarbons, 70
Chlorination
 abnormal operation, 351, 368, 373, 379
 additional resources, 432
 ammonia test for leaks, 370, 386

- amperometric titration, 574
- breakpoint, 338, 381, 587
- CHEMTREC, 406
- chloramination, 341
- chloramines, 336, 338–344
- chlorinator, 353–359, 368, 376–385
- chlorine, 333
- chlorine dioxide, 337, 391–399
- chlorophenol, 340
- contact time, 346
- container storage, 373, 389
- corrosion, 359, 376, 401
- critical factors, 346
- CT values, 346
- demand, 334, 347, 348, 584
- dichloramine, 339
- distribution system, 381
- dosage, 334
- DPD test, 383, 400, 574
- emergency repair kits, 386, 387
- equipment, 351, 358 (*see also* Chlorination equipment)
- failure, 385
- first aid, 404
- flow diagram, 350
- formulas, 366, 382
- free available residual chlorine, 338
- hazards, 401
- hypochlorinator, 351–353, 364
- hypochlorite, 337
- injection point, 346
- injector water supply, 369
- leaks, 361, 362, 369, 378, 385–389, 403
- mains, 351
- maintenance, 368, 385, 403
- math assignment, 431
- math, example problems, 424
- mixing, 346
- monitoring, 327
- monochloramine, 339
- nitrification, 341, 342
- normal operation, 351, 364, 372
- operation, 363–381
- operator training, safety, 405
- organic matter, 330, 338
- pathogen removal, 331
- performance, 363
- pH, 329, 334, 346, 391
- phenol, 340
- points of application, 349, 350
- population served, 327
- postchlorination, 9, 346, 349, 350, 381
- prechlorination, 9, 336, 341, 346, 349, 350, 381
- precursor, THM, 74, 82, 349
- process calculations, 347
- purpose, 8
- rechlorination, 349
- reducing agents, 329, 335, 346
- removing chlorine, 362, 363
- reporting, 327
- reservoirs, 351
- residual chlorine, 331, 334, 339, 342, 344, 346, 377, 399, 572, 584
- safety, 360, 362, 401–406
- sampling, 327, 328
- self-contained breathing apparatus, 362, 386, 401, 403
- storage of containers, 373, 389
- tanks, 351, 387
- tastes and odors, 9, 79, 340, 349, 381, 509
- temperature, 329, 346
- training, safety, 405
- trichloramine, 340
- trihalomethanes (THMs), 9, 330, 331, 349, 391
- troubleshooting, 380, 384, 385, 398
- turbidity, 329, 346
- variables, 330
- viruses, 326, 327, 330, 391
- waterborne diseases, 326
- water supply systems, 349
- wells, 349
- Chlorination equipment
 - air gap, 369
 - amperometric titration, 400
 - cathodic protection, 376
 - chemical solution tank, 351
 - CHEMTREC, 406
 - chlorinator, 353–359, 368, 376–385
 - chlorine dioxide, 391–399
 - connections, 363
 - containers, 359–363
 - corrosion, 359, 370, 376, 401
 - cylinders, 360–361
 - detection, chlorine leaks, 379, 385–389, 402
 - dew point, 370
 - diaphragm pump, 351, 352
 - DPD test, 383, 400, 574
 - eductor, 351
 - ejector, 351, 358
 - emergency repair kit, 387
 - evaporator, 370, 374
 - failure, 385
 - fusible plugs, 360, 361
 - hazards, 401
 - hypochlorinator, 351–353, 364
 - injector, 351, 356, 377, 384
 - installation, 351, 389
 - laboratory, 383, 393
 - leaks, 361, 362, 369, 378, 385–389, 403
 - lifting beam, 361
 - location, 389
 - maintenance, 368, 385, 403
 - manifold, 359, 390
 - math, example problems, 43
 - metering, 356, 358, 361
 - operation, 363–381
 - parts, 358
 - pigtail tubing, 363
 - plan review, 389
- Chlorinator, 353–359, 368, 376–385
- Chlorine
 - ammonia, 335, 338, 340, 342, 386
 - ammonia test for leaks, 370, 386
 - available residual, 334, 338
 - chemical, 20
 - CHEMTREC, 406
 - chloramines, 336, 338–344
 - concentrations, effects, 402
 - demand, 334, 347, 348, 584
 - detection, leaks, 378, 385–389, 403
 - detention rate curve, 345
 - disinfection action, 333
 - dose, 334, 348
 - emergency repair kits, 386, 387
 - first aid, 23, 404
 - frozen, 376
 - handling, 19
 - hydrogen sulfide, 336
 - hypochlorite, 336
 - hypochlorous acid, 334, 337, 339
 - ice, 376
 - leaks, 23, 361, 362, 364, 369, 378, 385–389, 403
 - maximum removal rate, 362, 390
 - on-site generation, 337
 - pH, 329, 334, 336, 391
 - physiological response, 402
 - prechlorination, 9, 336, 341, 346, 350, 351, 381
 - properties, 401
 - protection from, 403
 - rate of withdrawal, 369, 390
 - reaction with impurities, 335
 - reaction with water, 334
 - residual, 331, 334, 338, 339, 341, 344, 346, 377, 399, 584
- poppet valves, 365
- pressure controls, 354
- residual analyzer, 377, 378, 399
- review of plans and specifications, 389
- rotameter, 356
- safety, 360, 362, 368, 401–406
- self-contained breathing apparatus, 362, 386, 401, 403
- shutdown, 364
- solution feeders, 351–353
- startup, 364, 369
- storage, containers, 373, 389
- ton tanks, 361–362
- troubleshooting, 380, 384, 385
- trunnions, 361
- vacuum-controlled chlorinators, 353–359, 377
- valves, 360, 363, 365, 369, 375
- ventilation, 390
- water supply system, 369
- weighing, 360, 390
- wrench, 363
- yoke-type connectors, 362, 363

- Chlorine (*continued*)
 safety, 361
 use, 19
 withdrawal rate, 362, 390
- Chlorine demand
 algae, 82
 organics, 86
 solution, 585
 test, 584–588
 turbidity, 74
- Chlorine dioxide
 ammonia, 391
 chemical, 20
 corrosion, 392
 facilities, 391–399
 generation, 392
 iron and manganese, 338
 maintenance, 397, 398
 operation, 393–399
 pH, 391
 phenolic tastes and odors, 338
 reaction in water, 338
 reactions with impurities, 338
 safety, 393, 405
 shutdown, 396
 sodium chlorite, 393
 startup, 395
 taste and odor control, 340, 513
 trihalomethanes, 338, 391
 troubleshooting, 398, 399
- Chlorine residual test, 572–579
- Chloroform, 573
- Chlorophenol, 340, 510
- Chlororganics, 338, 505, 573
- Chromium, 5, 456
- Chromocult Coliform Agar Presence–Absence Membrane Filter Test, 589
- Circular basins, 213, 214
- Circular charts, electronic instrumentation, 30
- Cistern, water storage, 61
- Citric acid, 94, 97
- Clarification chemicals, 20
- Clarifiers, 214–215, 228, 229, 467
- Clear well
 operation, 12, 15
 purpose, 10
- Coagulation
 abnormal conditions, 164, 165
 alkalinity, 130
 alum, 20, 128, 129, 147, 153, 163, 179
 basins, 132
 calculation of dose, 156–162
 chemical feeders, 151
 chemicals, 20
 chemistry, 130, 170
 coagulant aids, 128, 129, 147
 color removal, 126
 definition, 126
 destabilization, 180
 detention time (mixing), 126, 129, 141
 dose, 153, 155, 163
 equipment operation, 171
 evaluation, 150
 floc formation, 133, 154, 165
 interaction with other processes, 136
 jar test, 130, 145
 laboratory tests, 138, 140, 145, 162, 164, 167, 169, 181
 maintenance, 170, 178
 math assignment, 199
 metallic salts, 128
 mixing, 130, 131
 monitoring process, 138, 140
 operation, 136–141, 170
 pathogen removal, 330
 pH, 130
 polymers, 126, 129, 147
 process, 126, 136, 138, 164
 purpose, 8, 126
 recordkeeping, 162, 164, 166, 168, 170
 safety, 159, 163, 169, 170, 178
 sampling, 169
 shutdown, 166
 solids-contact units, 227
 startup, 167
 sweep treatment, 179, 181
 taste and odor control, 504
 time, detention (mixing), 128, 129, 141
 troubleshooting, 165, 182
 turbidity removal, 129, 139, 163, 164
 visual observation, 138, 154, 164
 water quality, 138, 139, 161, 164, 165, 169
- Coliform Agar ES, 618
- Coliform bacteria, 70, 87, 327, 588
- Coliform-positive samples, 588
- Coliform tests
 Colilert method, 591, 616
 fermentation tubes, 590
 membrane filter, 607–610, 613
 Presence–Absence (P–A) Method, 614–616
- Colilert method, 591, 616
- Colilert test (enzyme substrate test), 616–618
- Colisure test (enzyme substrate test), 616–618
- Colitag Presence–Absence (P–A) Test, 589, 618
- Colloids, 126, 260
- Color, 7, 69, 82, 86, 126, 180, 275, 280, 282, 284, 296, 298, 561
- Colored water, complaints, 488
- Colorimeter, 577
- Colorimetric measurement, 560
- Combined residual chlorine, 584
- Communication, 36, 37
- Communication, plant, 164, 166
- Community water system, 6
- Complaints
 colored water, 488
 corrosion, 452, 458
 handling, 49
 recordkeeping, 37, 524
 tastes and odors, 488, 523, 524, 526
- Complete treatment, 72
- Composite sample, 25, 619, 623
- Compound substance, 537
- Compression settling, 209
- Computer programs
 energy conservation, 46
 instrumentation and controls, 31
- Concrete, 470
- Conditions, waterworks facilities, 497
- Conductivity, 111, 447
- Confined spaces, 50
- Connections, equipment, 362
- Conservation, 2
- Construction
 reservoirs, 86
 wells, 67
- Consumer complaints, 26, 49, 452, 488, 523, 524, 525
- Consumer demands for water, 3
- Contact, ozone, 420
- Contact time, chlorine, 346
- Containers
 chlorine, 359–363, 372, 389
 sampling, 628
- Contamination. *See also* Water quality
 groundwater, 2
- Controls. *See* Process instrumentation and controls
- Control valves, filter, 303
- Conventional filtration, 260, 276
- Copper, 5, 7, 455
- Copper Rule. *See* Lead and Copper Rule
- Copper sulfate, 20, 92, 93, 491, 508
- Corrosion
 additional resources, 528
 adverse effects, 438
 Aggressive Index (AI), 459
 alkalinity, 446
 annular space, 451, 452
 anode, 439
 asbestos-cement pipe, 466
 calcium carbonate, 446, 454, 456, 459–465
 cathode, 439
 cathode film formation, 442
 cathodic protection, 113, 118, 444, 466–472
 caustic soda, 461
 chemicals, 19, 20, 462
 chemical tests, 454–459
 chemistry, 438, 441
 clarifiers, 467
 complaints, 459
 concrete, 470
 conductivity, 447
 control, 19, 20, 459–472
 corrosivity, 438, 453, 458
 coupons (steel specimen), 453
 currents, electrical, 442, 443, 467, 470

- damages, 438
 - dead ends, 450
 - definition, 438
 - dezincification, 442
 - differential-concentration cell, 438
 - dissolved oxygen, 441, 447, 451, 454
 - dissolved solids, 447
 - drinking water, 438
 - Driving Force Index (DFI), 459
 - electrolysis, 444, 470, 471
 - electrolyte, 440
 - Enslow column, 456, 464
 - erosion corrosion, 445, 469–472
 - external, 469–472
 - filters, 298, 299, 304, 467
 - floculators, 466, 467
 - flow diagram, 460
 - flow tests, 453
 - galvanic cell, 438, 440, 441, 442, 443
 - galvanic series, 440
 - hardness, 447
 - hexametaphosphate, 466
 - hydrated lime, 461
 - impressed current, 467
 - indices, 456, 459
 - inhibitors, 442
 - Langelier Index (LI), 457–459
 - Larson method, 457
 - Lead and Copper Rule, 448, 452, 473
 - leaks, 453
 - lime, 462
 - Marble Test, 448, 456, 463
 - material examination, 453
 - math assignment, 482
 - maximum contaminant level goal (MCLG), lead and copper, 476
 - methods of control, 10
 - monitoring water quality, 473, 475
 - oxygen concentration cell, 450
 - oxygen, dissolved, 441, 447, 451, 454
 - pH, 447, 451, 457
 - polyphosphate compounds, 448, 466
 - problems, 438
 - process discussion, 438
 - purpose of control, 10
 - quicklime, 461
 - recordkeeping, 481
 - regulations, 448, 453, 473
 - Ryznar Index (RI), 459
 - sacrificial anode, 441
 - Safe Drinking Water Act (SDWA), 473
 - sampling, 476
 - sedimentation basins, 233, 252
 - silica compounds, 448, 466
 - soda ash, 461
 - soils, 438, 439, 444, 469
 - solids-contact units, 233
 - steel, 470
 - stray current electrolysis, 444, 470
 - sulfate-reducing bacteria, 449
 - temperature, 445
 - total dissolved solids, 458
 - toxic metals, 448, 455
 - trimetaphosphate, 464
 - troubleshooting, 472
 - tubercle, 440, 451
 - tuberculation, 438
 - upflow clarifiers, 234
 - variables, 443
 - velocity, water, 445
 - visual observations, 452, 468, 470
 - zinc coatings, 466
 - Corrosion problems
 - adverse effects, 438
 - chlorination, 359, 375, 401
 - chlorine dioxide, 391
 - complaints, 459
 - copper, 455
 - filtration, 298, 299, 304, 467
 - Lead and Copper Rule, 448, 452, 473
 - total dissolved solids (TDS), 458
 - Corrosive gases, 444
 - Corrosive materials, 551
 - Corrosivity, 7, 438, 453, 459
 - Costs
 - energy conservation, 45, 46, 48
 - maintenance, 44
 - operation and maintenance, 3, 44
 - particle counter, 314
 - treatment, 2, 3, 81, 82, 84
 - water rates, 2
 - watershed management, 86
 - Coupons (steel specimen), 453
 - CPR. *See* Cardiopulmonary resuscitation (CPR)
 - Cross-connection, 67, 499, 501
 - Cryptosporidiosis, 62, 588
 - Cryptosporidium*, 307, 310, 312, 315, 329, 423, 496
 - CT value, 346
 - Culture strategy, test, 589
 - Culture tubes, 539
 - Current, electric, 438, 442, 443, 467, 470
 - Currents, sedimentation basins, 207, 208
 - Cuts, injury, 550, 554
 - Cylinders, chlorine, 360–361
 - Cysts, 330
- D**
- Daily procedures, operation, 11–15
 - Dairies, 497
 - Damages, corrosion, 438
 - Dams and reservoirs. *See also* Reservoirs
 - draining, 108
 - inspection, 108
 - maintenance, 108–109
 - vegetation, 109
 - Data recording, 548
 - Data sheets, jar test, 149
 - Day tank, 159
 - DBPR. *See* Disinfectants and Disinfection Byproducts Rule (DBPR)
 - Dead ends
 - corrosion, 450
 - tastes and odors, 498, 501
 - Debris dams, 204, 205
 - Decant water, 494
 - Dechlorination, 509
 - Degasification, 505, 507
 - Deionized water *versus* distilled water, 584–585
 - Demand, chlorine, 334, 347, 348
 - Demand for water, 3, 17
 - Demineralized water, 592
 - Density, 204, 207
 - Density currents, 207, 208, 246
 - Depolarization, 447
 - Depth sampling, 625, 626
 - Design, sedimentation basins, 208, 219
 - Destabilization, 180
 - Destratification, 102–109
 - Detection, chlorine leaks, 379, 385–389, 403
 - Detention rate curve, chlorine, 345
 - Detention time
 - chlorine, 346
 - coagulation, 126, 140, 142
 - curves, 144, 145, 345
 - definition, 141, 144, 145
 - floculation, 133, 141, 142
 - nitrification, 342
 - reservoirs, 18
 - sedimentation basins, 219–223, 233
 - solids-contact units, 233
 - Dew point, 370
 - Dezincification, 442
 - DFI. *See* Driving Force Index (DFI)
 - Diallyldimethylammonium (DADMA), cationic polymers, 276
 - Diaphragm pump, 351, 352
 - Diatomaceous earth, 265
 - filtration, 264, 269, 270
 - Diatoms, 96, 340
 - Dichloramine, 339, 340, 573
 - Dielectric, 442
 - Die-offs, 491, 494
 - Differential-concentration cell, 438
 - Diffusers, 131
 - Digital indicators, 30
 - Dilution water, 593
 - Dimictic, 75, 83
 - Direct filtration, 72, 260, 276, 277, 297
 - Direct runoff, 60
 - Dirty water, 83
 - Disasters, 35
 - Discharge standards, sludge, 27
 - Diseases, waterborne, 326
 - Disinfectants and Disinfection Byproducts Rule (DBPR), 307, 328
 - Disinfection. *See also* Chlorination
 - action, 8, 333
 - additional resources, 432
 - agents of disinfection, 331
 - bacterial cells, 331

Disinfection (*continued*)

bacteria, pathogenic, 326
 bitter taste, 332
 breakpoint chlorination, 338, 381
 bromine, 332
 byproducts, 7, 179, 332
 calculations, 347
 chemical disinfectants, 332
 chemicals, 19, 20
 chlorination, 9, 333
 chlorine, 333
 chlorine dioxide, 337, 391–399
 coliform, 327
 contact time, 346
 critical factors, 346
Cryptosporidium, 328, 423
 CT values, 346
 cysts, 330
 disease, waterborne, 326
 dosage, 334
 enzymes, 333
 fecal coliforms, 588
 flow diagram, 350
 formulas, 366, 382
Giardia, 7, 327, 346, 423
 giardiasis, 326
 heat, 332
 hepatitis, 326
 hypochlorite, 336
 inorganic matter, 330
 iodine, 332
 math assignment, 431
 math, example problems, 424
 maximum contaminant level, 327
 microbial standards, 327
 microorganisms, 330–331
 mixed-oxidants system, 423–424
 monitoring, 327
 organic matter, 330, 338
 oxidation, 83
 ozone, 332, 417
 parasites, 326
 pathogenic organisms, 326
 pathogen removal, 330
 pH, 329, 334, 346, 391
 physical means, 331
 population served, 328
 postchlorination, 9, 346, 349, 350, 381
 prechlorination, 9, 336, 340, 346, 349, 350, 381
 process calculations, 347
 processes, 331–349
 purpose, 8
 reducing agents, 329, 335, 346
 removal processes, pathogens, 330
 reporting, 328
 residual chlorine, 331, 334, 338, 339, 342, 346, 377, 399–401, 572, 584, 586
 sampling, 327, 328
 spore-forming bacteria, 330
 standards, microbial, 327

sterilization, 326
 taste, bitter, 332
 temperature, 329, 346
 trihalomethanes (THMs), 9, 330, 331, 349, 391
 troubleshooting, 380, 384, 385, 398
 turbidity, 329, 346
 ultrasonic waves, 332
 ultraviolet rays, 332, 414
 ultraviolet (UV) systems, 331, 406, 414
 variables, 329
 viruses, 327, 330, 391
 waterborne diseases, 326
 Disinfection byproducts (DBPs), 7, 179, 332
 Disposal of sludge, 26
 Dissolved oxygen (DO)
 algae, 82
 corrosion, 441, 447, 450, 454
 depletion, 82, 85, 92, 105, 109, 492
 diurnal cycle, 493
 fish kills, 82
 photosynthesis, 81
 profile, reservoir, 76, 77
 reservoirs, 102–109
 supersaturation, 82, 493
 Dissolved solids, corrosion, 447
 Distilled water
 in culture media, 592
 versus deionized water, 585
 in lab samples, 571
 Distribution systems
 disinfection, 585
 flow regulation, 15
 flushing, 83
 oxidation, 83
 sampling, 620–623
 tastes and odors, 497, 501, 503
 Diurnal dissolved oxygen (DO) cycle, 493
 DO. *See* Dissolved oxygen (DO)
 Dose, chlorine, 334, 348
 Double-deck basins, 213
 DPD Colorimetric Method, 575–579
 DPD test, 342, 383, 399
 DPD titrimetric method, 574
 Drag-chains, 211, 240, 241
 Draining reservoirs, 108
 Drawdown, wells, 67
 Drinking water
 corrosion, 438
 laws, 326
 monitoring program, 25, 28
 quality, 12, 15
 quantity, 12–14
 regulations, 7
 safety, 326
 sampling, 5, 619–628
 tastes and odors, 489
 turbidity removal, 7, 25
 Driving Force Index (DFI), 459
 Drowning, safety prevention measures, 49
 Dual media, 263, 267, 268

Duties, operator, 51
 Dysentery, contamination of water supply, 62

E

Earthquakes, 35
 Earthy tastes and odors, 81, 494, 503, 527
 EBCT. *See* Empty Bed Contact Time (EBCT)
E. coli (EPA Method 1603), 613
 E*Colite Test, 589, 618
 Eddy currents, 207
 EDTA titrant, 571
 Eductor, 351
 Effective size, granular sample, 266
 Effective water depth, 225
 Efficiency
 filtration, 267, 286, 296
 sedimentation basins, 204, 245
 Ejector, 351, 358
 Electrical charge, particles, 207
 Electrical equipment, safety, 254
 Electrical signal transmission, 31
 Electric motors, 45
 Electric shock, 550, 554
 Electrochemical probe, 560
 Electrochemical reaction, 438
 Electrochemical series, 440
 Electrolysis, 444, 470, 471
 Electrolytic cell, 439
 Electromotive series, 440
 Electron, 440
 Electronic signal transmission, 30
 Emergency
 alum feeder, 34
 chemical spills, 32
 chlorine repair kits, 387
 chlorine residuals, 33
 communications, 36
 conditions, 32
 corrosion control, 34
 disasters, 35
 earthquakes, 35
 equipment, 33
 equipment repairs, 44
 errors, 33
 failures, 32
 filters, 34
 fires, 35
 flash mix, 34
 flocculators, 34
 floods, 35
 grit basin, 33
 intake screens, 33
 natural disasters, 35
 polymer feeder, 34
 postchlorination, 34
 power, 34
 prechlorination, 34
 procedures, 32

- rapid mix, 34
 - raw water changes, 32
 - red alert, 32
 - repairs, 44
 - sedimentation tank, 34
 - spills, chemicals, 32
 - treatment processes, 32
 - turbidity breakthrough, 35
 - Emergency response procedure, 166
 - Empty Bed Contact Time (EBCT), 522
 - Endpoint, 565
 - Endrin, 6
 - Energy conservation
 - air conditioning, 45
 - capacitors, 46
 - computer use, 46
 - conservation, 45
 - consideration, 46
 - cost analysis, 46, 48
 - electric motors, 46
 - heating, 45
 - lighting, 45
 - management, 46
 - mixing, 132
 - power management, 46
 - procedures, 45
 - ventilating, 46
 - Enforcement, regulations, 306
 - Enhanced coagulation
 - apparent color, 180
 - charge chemistry, 180
 - chemical reactions, 180
 - color, 179, 180
 - jar test, 181
 - process control, 180
 - recordkeeping, 168
 - safety, 168
 - shutdown, 166
 - startup, 167
 - sweep treatment, 179, 181
 - troubleshooting, 182
 - true color, 180
 - Enslow column, 456, 464
 - Enzymes, 333
 - Enzyme substrate coliform test, 591
 - Enzyme substrate tests, 589, 616–618
 - Epidemiology, 66
 - Epilimnion, 75
 - Equipment. *See also* Laboratory equipment
 - chlorination, 351, 356
 - coagulation, 170
 - electrical, 50
 - electrochemical probe, 560
 - emergency, 33
 - filtration, 262, 263, 264, 268, 273–274
 - flocculation, 133, 135
 - lab basics, 534–538
 - laboratory, 538–545
 - ozone, 417, 419
 - records, 36, 43
 - sampling, 625
 - sedimentation basins, 252
 - ultraviolet (UV) systems, 407
 - Erosion corrosion, 445
 - Erosion, soil, 88
 - Escherichia coli (E. coli), 613
 - Eutrophic, 77, 87
 - Eutrophication, 87, 89, 492
 - Evaporator, chlorine, 370, 374
 - Evapotranspiration, 61, 90
 - Explosions, 550, 551
 - Explosive atmospheres, 49
 - External corrosion, 469–472
 - Eye burns, first aid, 23
- ## F
- Facultative bacteria, 588
 - Failures, 32, 33
 - chlorination, 385
 - Farming practices, affect on watershed, 89
 - FC test. *See* Fecal coliform (FC) test
 - Fecal coliform (FC) test, 599, 611
 - E. coli, 588
 - Feeders, chemical
 - adjustment, 172
 - calibration, 173
 - coagulation, 151
 - Feedlots, animals, 497
 - Fermentation tubes, 590
 - Ferric chloride, 20
 - Ferric sulfate, 20
 - Ferrous sulfate, 20
 - Fertilization, 88
 - Filter aid chemicals, 297
 - Filter Backwash Rule, 272
 - Filtration
 - abnormal conditions, 296
 - activated carbon, 263, 274
 - additional resources, 320
 - administration, 294
 - air binding, 299
 - algae, 284, 296, 297, 304
 - anthracite coal, 263, 265, 267, 269
 - backwashing, 270, 286, 292, 301–302
 - boils, 283, 284, 296, 297, 298
 - breakthrough, 266, 270, 281, 296, 297, 298, 315
 - bumping a filter, 283
 - calculations, 286–294
 - color, 275, 276, 280, 282, 284, 296, 298
 - control systems, 273, 274, 303
 - control valves, 303
 - conventional, 260, 276
 - corrosion, 298, 299, 304, 466, 467
 - diatomaceous earth, 264, 269, 270
 - direct, 72, 260, 276, 277, 297
 - dual media, 263, 269
 - effective size, granular sample, 266
 - efficiency, 267, 287, 294
 - equipment, 262, 263, 264, 268, 273–274
 - filter aid, 297, 298
 - flow diagram, 261
 - fluidized media, 270
 - formulas, 287, 291
 - galleries, 305
 - garnet, 263, 265, 267, 268
 - Giardia removal, 309
 - gravity, 262, 263, 267, 268, 269
 - head loss, 266, 280, 281, 296, 298, 299, 303
 - inline filtration, 276, 277
 - instrumentation, 294
 - interaction with other processes, 275
 - laboratory, 278, 281, 284, 297, 298
 - layout, 267
 - maintenance, 283, 294, 304
 - math assignment, 320
 - mechanisms, 262
 - media, 8, 260, 262, 263, 265, 268, 283, 284, 294
 - expansion, 284
 - loss, 280, 283, 284, 291, 294, 297, 298
 - mixed media, 263, 268
 - monitoring, 281, 282, 284, 294, 298, 303
 - mudballs, 270, 272, 280, 283, 284, 296, 298, 299, 304
 - multi-media, 263, 268, 269
 - normal conditions, 278, 281
 - operating deck, 273
 - operation, 267, 270, 278, 281, 284, 296, 302–303
 - pathogen removal, 331
 - percent backwash water, 281, 291, 294
 - performance, 265, 284, 286, 294, 298
 - polymers, 129, 276
 - precoat, 262, 264
 - pressure, 262, 263
 - pretreatment, 275
 - process actions, 280, 284, 296, 298
 - process control, 278
 - process description, 280
 - production, 265, 267, 294
 - purpose, 8, 260, 261
 - rapid sand, 262
 - rate, 263, 265, 267, 287, 290, 297
 - recordkeeping, 294, 295, 304
 - ripening period, 276, 282
 - run time, 281, 297, 298
 - safety, 305
 - sampling, 284, 287
 - shortened filter runs, 81, 298
 - shutdown, 300, 303
 - slow sand, 262
 - startup, 300, 302
 - surface wash, 271, 272, 297, 301, 303
 - Surface Water Treatment Rule (SWTR), 307
 - time, 81, 281, 297, 298
 - troubleshooting, 298
 - turbidimeter, 279, 280, 294, 303
 - turbidity, 278, 281, 284, 294, 297, 298, 303, 308 (*see also* Particle counter)
 - breakthrough, 266, 270, 282, 296, 297, 298, 316

- Filtration (*continued*)
 types of filters, 262
 underdrains, 262, 263, 268, 281
 uniformity coefficient, 267
 unit filter run volume (UFRV), 281, 288, 290, 294, 730, 746
 visual observations, 284
 wash water, 300, 301
 water quality, 276, 282, 284, 294, 303
- Fire
 blanket, uses, 555
 classifications, 556
 extinguisher, 556
 laboratory, 550, 555
 plant, 35
 wild, 73, 90
- First aid
 chemicals, 24
 chlorine, 23, 405
 laboratory, 552
- First-draw sampling, 627
- Fish
 kills, 82, 494
 reservoirs, 85, 96, 101
- Fishy tastes and odors, 503, 509
- Flame-polished glass, 555
- Flammable or explosive materials used in
 laboratories, 550
- Flash mixing
 coagulation, 126, 130–132, 140
 emergency, 34
 methods, 129, 131
 purpose, 8
- Flights, sludge removal, 240, 241
- Floc
 characteristics, 206
 formation, 133, 155, 165
 sludge, 150
- Flocculation
 abnormal conditions, 164, 165
 baffles, 134, 135
 ballasted, 183–198
 basins, 134, 135
 chemical feeders, 151
 chemistry, 130
 color removal, 126
 definition, 128
 description, 133, 141
 detention time, 133, 141, 142
 emergency, 34
 equipment operation, 171
 evaluation, 151, 155
 flocculators, 133
 floc formation, 133, 154, 165
 interaction with other processes, 136
 jar test, 136, 145–155, 181
 laboratory tests, 139, 140, 145–155, 164, 165, 169, 180
 maintenance, 170, 177
 math assignment, 199
 mixing, 130–136
 monitoring process, 138, 140
 operation, 137–141, 170
 purpose, 133, 136
 recordkeeping, 162, 166, 168, 170
 safety, 163, 168, 170, 178
 sampling, 251
 short-circuiting, 134, 139
 shutdown, 166
 solids-contact process, 136, 227
 speed adjustment, 139
 startup, 166
 stirrers, 133
 taste and odor control, 505, 527
 temperature, 140
 troubleshooting, 165
 turbidity removal, 138, 163, 164
 visual observations, 139, 154, 164
 water quality, 139, 140, 162, 164, 165, 169
- Flocculators
 corrosion, 466, 467
 horizontal, 133, 134
 paddle, 133
 propeller, 133
 tapered-energy mixing, 135
 turbine, 133
 vertical, 133
- Flood gates, 108
- Floods, emergency, 35
- Flow pattern, 8–10, 205, 261, 350, 460
- Flow regulation
 calculations, 18
 clear wells, 16
 daily variation, 15–18
 demand-feedback, 16
 demands, 15, 17
 distribution system, 16
 historical records, 16
 pressures, 16
 pumping rates, 14, 16
 storage, 16
 system demands, 16
 treatment processes, 18
 unusual events, 16
 weather affects, 16
- Flow tests, corrosion, 453
- Fluidized media, 270
- Fluoridation, 19, 20
- Fluoride, 5, 7, 19, 20
- Fluosilicic acid, 20
- Flushing, 83, 498, 503
- Flushing agents (MBAS), 7
- Formazin Turbidity Units (FTU), 562
- Formulas
 algae control in reservoirs, 97
 chemical feeders, 151
 chlorination, 365, 382
 detention time, 141
 disinfection, 366, 381
 filtration, 287, 291
 jar test, 152
 laboratory, chemicals, 536–538
 polymer solutions, 156
 sampling, 621
 sedimentation, 220, 234
 solids-contact units, 234
 taste and odor control, 518
 volume, 142
- Frazzle ice, 107, 120
- Free available residual chlorine, 338
- Free residual chlorine, 573
- Frozen chlorine, 376
- Frozen reservoir, 106, 116
- FTU. *See* Formazin Turbidity Units (FTU)
- Fulvic acid, 179
- Fusible plugs, 360, 361
- G**
- GAC. *See* Granular activated carbon (GAC)
- Galleries, filtration, 305
- Galvanic cell, 438, 440, 441, 442
- Galvanic series, 440
- Garnet, 263, 265, 267, 269
- Gates
 flood, 108
 intake, 117
 outlet, 103, 112, 117
- Geological log, 66
- Geosmin, 81, 489, 527
- Giardia*, 7, 74, 309, 312, 315, 327, 346, 423, 496
- Giardia lamblia*, 307, 308
- Giardiasis, 62, 74, 326, 588
- Glasses, safety, 551
- Glassware, laboratory, 542–545, 592
- Grab sample, 25, 137, 313, 623, 625
- Grading, soil, 89
- Granular activated carbon (GAC), 514, 522
- Grassy tastes and odors, 79, 503, 509
- Gravity filters, 262, 267, 268
- Grid systems, mixing, 132
- Grit basin, 33, 204, 206
- Groundwater
 recharge, 65
 sampling, 620
 source, 61, 62
- H**
- Hands-only CPR, 405
- Hardness
 control, 10
 corrosion, 450
 removal, 10
- Hardness test, 570–572
- Hazardous materials
 disposal, 554, 555
 laboratory, 550–551
- Hazardous spills, 89
- Hazardous wastes, 3
- Hazards, chlorination, 401

- Head loss
 coagulation, 132
 filtration, 265, 280, 282, 294, 298, 299, 302
- Health hazards
 disease, 62
 groundwater recharge, 64
 laboratory, 550
- Heat, disinfection, 332
- Heating buildings, 45
- Hepatitis, 62, 326
- Herbicides, 89
- Heterotrophic bacteria, 7, 340
- Hexametaphosphate, 466
- High-rate settlers, 214, 217
- High resolution redox (HRR), 400
- High Test Hypochlorite (HTH), 20, 336, 522
- Historical records, 16
- Holding time, sampling, 627, 628
- Horizontal flocculators, 133, 134
- Household plumbing, 498
- HRR. *See* High resolution redox (HRR)
- Humic acid, 179
- Hyacinths, water, aquatic plants, 78
- Hybrid control systems, 31
- Hydrated lime, 20, 461
- Hydraulic mixing, 105, 131
- Hydraulic signal transmission, 30
- Hydraulics, sedimentation, 207
- Hydrocyclones
 clogging, 192
 feed solution, 191
 inlet pressure, 192
 maintenance, 198
 microsand
 addition, 189
 concentration, 186
 Safety Data Sheet (SDS), 190
 overflow, 192
 startup, 185
 underflow, 191
- Hydrogen sulfide
 chlorine reaction with, 335
 reservoirs, 82, 84, 111
 tastes and odors, 503
- Hydrologic (water) cycle, 61
- Hydrophobic, 515
- Hygiene, laboratory, 551
- Hypochlorinator, 351–353, 364
- Hypochlorite
 calcium hypochlorite, 20, 336
 calculation example, 428
 disinfection, 336
 HTH (High Test Hypochlorite), 20, 336, 522
 hypochlorous acid, 334, 336, 339, 573
 ion, 334
 reactions with water, 336
 safety, 405
 sodium hypochlorite, 20, 336
- Hypochlorous acid, 334, 336, 339, 573
- Hypolimnion, 75, 77, 85, 104, 105
- I**
- Ice
 chlorine, 376
 intake-outlet structures, 116, 120
- IDLH. *See* Immediately Dangerous to Life or Health (IDLH)
- IESWTR. *See* Interim Enhanced Surface Water Treatment Rule
- Imhoff cone, 518
- Immediately Dangerous to Life or Health (IDLH), 390
- Impermeable, 61
- Impressed current, 467
- Impurities in water, 126
- Inclined intake structures, 116
- Indicators, 560
- Indices, corrosion, 456, 459
- Industrial discharges, 88
- Inhalation or swallowing, first aid, 24
- Inhibitors, corrosion, 442
- Injection point, chlorine, 346
- Injector, chlorine, 351, 353, 356, 377, 384
- Injector water supply, 356
- Inlet zone, 208
- Inline filtration, 275, 277
- Inorganic, 5, 69
 compounds, 537
 materials, 489
 matter, 330
- In-plant sampling, 620
- Inspection
 corrosion, 452
 maintenance, 38
 reservoirs, 99
 taste and odor control, 498, 500
- Installation, chlorination equipment, 351, 389
- Instructions, maintenance, 38
- Instrumentation, filtration, 294. *See also* Process instrumentation and controls
- Instrument-based water quality tests, 557–564
- Instrument calibration, 561
- Intake gates, 113
- Intake screens, 33, 106, 112–117
- Intake structures. *See also* Outlet structures
 additional resources, 121
 cathodic protection, 113
 facilities, 112–117
 gates, 113–117
 ice, 108, 116, 120
 inclined, 116
 math assignment, 121
 multilevel, 62, 79, 114
 operation and maintenance, 119
 records, 120
 safety, 120
 screens, 112–117
 single-level, 113, 114
 valves, 115
 withdrawal level, 116–117
- Interaction with other processes
 coagulation-flocculation, 136
 filtration, 275
 sedimentation, 204
- Interim Enhanced Surface Water Treatment Rule (IESWTR), 307, 327
- Inventory records, 37
- Iodine, disinfection, 332
- Iodine number, 514
- Ion, 439, 537
- Iron, 7
- Iron and manganese control
 chlorine dioxide, 337
 purpose, 10
 reservoirs, 83, 84
 SMCL (secondary maximum contaminant level), 7
- Iron bacteria, 449
- Irrigation runoff, 2, 60, 495, 496
- Irrigation water, 64
- J**
- Jar test
 alkalinity monitoring, 582
 apparatus, 137, 147, 580
 coagulation, 130, 145, 165
 coagulation/flocculation, 579–584
 data sheets, 149
 definition, 130
 dosages, 138
 enhanced coagulation, 181
 floc, 148, 150
 flocculation, 137, 147
 frequency, 151
 jar shape, selecting, 579
 mixing speeds and times, 148
 odor control, 505, 510, 516, 517, 519
 polymer and coagulant aid dosages, 581
 procedure, 145, 579
 reagents, 147
 streaming current meter, 155
 taste and odor control, 505, 509, 516, 517, 519
 use, 137
- Jobs, knowledge and skills needed, 52
- K**
- Kemmerer depth sampler, 626
- Kjeldahl nitrogen, 499
- L**
- Labeling sample container, 627
- Laboratory. *See also* Laboratory equipment; Laboratory glassware; Laboratory procedures; Laboratory safety

- Laboratory (*continued*)
- chlorination, 383, 399
 - coagulation-flocculation, 139, 140, 145–156, 164, 165, 169, 181
 - disinfection, 378, 399
 - filtration, 278, 282, 284, 297, 298
 - jar test, 145, 579
 - metric system units, 534–536
 - odor control, 526
 - recordkeeping, 39–41, 111
 - safety, 112
 - sedimentation, 251
 - taste and odor control, 525
- Laboratory equipment
- autoclave, 542
 - colorimeter, 574–577
 - pH meter, 560
 - turbidimeter, 563
- Laboratory glassware
- culture tube, 539
 - meniscus, 542
 - pipets, 543
 - test tubes, 539
- Laboratory procedures
- accident prevention, 552–556
 - acid titration curve, 566
 - additional resources, 534, 559, 560, 570, 578, 588, 607, 612, 614
 - additional test methods, 618
 - alkalinity test, 565–570
 - bacterial cultures, 589
 - basic concepts, 534–538
 - biological tests, 588–618
 - calibration, 561
 - chain-of-custody protocol, 627
 - chapter review, 630
 - chemical burns, 555
 - chemical names, 536–538
 - chemical solutions, 545–548
 - chemical storage and movement, 552
 - chlorine demand test, 584–588
 - chlorine residual test, 572–579
 - coliform bacteria, 588
 - Colilert method, 591, 616
 - corrosive materials, 551
 - data recording, 548
 - enzyme substrate tests, 616–618
 - equipment, 538–542 (*see also* Laboratory equipment)
 - erratic laboratory results, 561
 - error sources, 619
 - Escherichia coli*, 613
 - fecal coliform, 588
 - fire extinguisher, 555–556
 - formulas, 536–538, 621–622
 - glassware, 542–545 (*see also* Laboratory glassware)
 - hardness test, 570–572
 - hazardous materials, 550
 - hazards in laboratory, 550–551
 - identification strategies, testing, 590
 - instrument-based tests, 557–564
 - jar test, 579
 - labeling chemicals, 553–554
 - liquid media sterilization, 593
 - math assignment, 629
 - media, 590
 - media preparation and storage, 593
 - membrane filter (MF) method, 607–611
 - membrane filter method-*E. coli*, 613–614
 - membrane filter procedure
 - modifications, 611–612
 - meniscus, 543
 - metric system, 534–536
 - microbial testing material, 592
 - most probable number (MPN)
 - procedure, 590, 596–607
 - MPN Index, 601, 605
 - multiple tube fermentation, 590, 594–607
 - notebooks, 548
 - pH test, 559–561
 - plant process tests, 579–588
 - Presence-Absence (P-A) method, 591, 614–616
 - quality control, 549
 - recordkeeping, 548
 - reference-type sample, 549
 - reporting lab results, 627
 - safety, 550–556
 - safety and hygiene, 551
 - sampling, 619–627 (*See also* Sampling)
 - devices, 624
 - techniques, 625–627
 - solutions, 545
 - standardized solutions, 566
 - techniques, 538–542, 553
 - temperature test, 557
 - test methods, overview, 589–592
 - thermometer types, 557–558
 - titrations, 564–579
 - total coliform bacteria testing, 594–618
 - toxic fumes, 555
 - turbidity test, 561
 - turbidity units (TU) and measures, 562
 - using glassware, 542–545
 - waste disposal, 555
 - water quality tests, 557–618
 - worksheets, laboratory, 548, 549
- Laboratory safety
- accident prevention, 552
 - acids, 551
 - additional resources, 556
 - bases, 551
 - bruises, 550
 - burns, 550, 555
 - caustics, 551
 - chemical storage, 552
 - corrosive materials, 551
 - cuts, 550, 554
 - electric shock, 550, 554
 - explosions, 550, 551
 - fires, 550, 555–556
 - first aid, 552
 - flammable materials, 551
 - glasses, safety, 551
 - hazardous materials, 550–551
 - hazards, 550
 - hygiene, 551
 - mercury, 553
 - movement of chemicals, 552–553
 - Occupational Safety and Health Administration (OSHA), 550
 - personal safety, 551
 - prevention of accidents, 552
 - protective clothing, 552
 - shock, 550, 554
 - techniques, 553
 - toxic materials, 550, 555
- Lab results, reporting, 627
- Lagoons, sludge, 494
- Lake destratification, additional resources, 102
- Lakes, 62. *See also* Reservoirs
- Land subsidence, 64
- Land use, 90
- Langelier Index (LI), 453, 457–458
- Larson method, 457
- Laundering weirs, 155, 210
- Lauryl tryptose broth, 590
- Laws, drinking water, 326–329
- Lead, 7, 473
- Lead and Copper Rule
- analytical methods, 477
 - certification requirements, 477
 - first-draw sampling, 627
 - health concerns, 473, 474
 - lead ban history, 442
 - lead service line replacement, 479
 - maximum contaminant level goals (MCLGs), 475
 - monitoring deadlines, 475
 - monitoring requirements, 474, 475
 - public education, 473, 480
 - recordkeeping requirements, 481
 - regulations, 473–475
 - reporting requirements, 473, 480, 481
 - sampling procedures, 475–476
 - treatment requirements, 478
- Leaks
- chlorine, 23, 360, 362, 369, 378, 385–389, 403
 - corrosion, 452
- Legionella, 307
- LES endo agar, 590
- LI. *See* Langelier Index (LI)
- Lifting beam, chlorine tanks, 361
- Lighting, energy conservation, 45
- Lime, corrosion control, 461
- Limited resource, water, 2
- Lindane, 6
- Liquid media sterilization, 593
- Littoral zone, 78
- Livestock grazing, 89
- Location, chlorination equipment, 389

Logarithm, 457–459
 Logging, 73
 Long Term 1 Enhanced Surface Water
 Treatment Rule (LT1ESWTR), 307
 Long Term 2 Enhanced Surface Water
 Treatment Rule (LT2ESWTR), 307

M

Mains, disinfection, 351
 Maintenance
 ballasted flocculation, 196
 budget, 38
 chlorination, 368, 385, 402
 chlorine dioxide, 396
 coagulation, 170
 costs, 38, 44
 dams, 108
 emergency repairs, 38, 44
 equipment, 42
 filtration, 284, 294, 304
 flocculation, 170
 inlet structures, 116
 inspection, 42
 instructions, 38
 intake screens, 106–107, 112–117
 intake structures, 119–120
 management, records, 43
 odor control, 497, 503, 518
 operator's duties, 38
 ozone, 420–422
 particle counter, 316–320
 planning, 38
 preventive, 38
 program, 38
 records, 36
 reservoirs, 108
 routine, 42
 scheduling, 38
 sedimentation, 252–253
 solids-contact, 253
 spare parts management, 43–44
 taste and odor control, 497, 503, 518
 tools, 42
 training, 44–45
 ultraviolet (UV) systems, 414–417
 work orders, 44
 Management
 energy conservation, 46
 maintenance, 38
 records, 43
 Manganese, 7
 Manifold, 359, 390
 Manual sampling, 624
 Manual sludge removal, 240
 Marble Test, 448, 456, 463
 Mass concentration, 545
 Material examination, corrosion, 453
 Math assignment
 basic math overview, 53
 chlorination, 431
 coagulation, 199
 corrosion control, 482
 disinfection, 431
 filtration, 320
 flocculation, 199
 laboratory procedures, 629
 sedimentation, 255
 source water, reservoir management,
 and intake structures, 121
 taste and odor control, 528
 Maximum contaminant level (MCL)
 (primary standards), 5, 6, 327
 organic chemicals, 306
 MBAS (foaming agents), 7
 m-ColiBlue24® Test, 589, 618
 Mean flow velocity, 225
 Mechanical equipment, safety, 50
 Mechanical mixing, 105, 132
 Mechanical rakes, 240
 Mechanical signal transmission, 29
 Mechanical sludge removal, 240,
 241, 247
 Media
 expansion, 284
 filtration, 8, 260, 262, 265, 268, 283,
 284, 294
 loss, 280, 283, 284, 291, 294, 297, 298
 preparation and storage, 593–594
 Membrane filter
 counting colonies, 612
 inoculation, 608
 need, 591
 Membrane filter (MF) method, 589,
 607–611
 Membrane filter method–*E. coli* (EPA
 Method), 589, 591, 613–614
 Membrane filter procedures modifications,
 611–612
 Meniscus, 542
 Mercury, 5, 408, 417, 553
 Mesotrophic, 78
 Metalimnion, 75, 76, 83, 85
 Metallic salts, 128
 Metering, chlorine, 356, 361
 Methoxychlor, 6
 Methylisoborneol (MIB), 81, 489, 527
 Methyl orange alkalinity, 94
 Metric system, 534–536
 MIB. *See* Methylisoborneol (MIB)
 Microbes, 590
 Microbial populations, 491, 492
 Microbial standards, 7, 327
 Microbial testing, materials, 592
 Micron, 129
 Microorganisms, 330
 Microprocessors, 31
 Microscopic organisms controlling,
 101
 Mining, 88, 90
 Mixed media, 263, 268
 Mixed-oxidant disinfection,
 423
 Mixing
 baffles, 131, 133, 135
 blenders, pumped, 132
 chemicals, 130, 131
 chlorine, 345
 coagulation, 130, 132
 diffusers, 131
 energy consumption, 131
 flash, 126, 131, 132, 139
 flocculation, 130–133, 139
 grid systems, 132
 hydraulic, 105, 131
 mechanical, 105, 131
 paddles, 132, 133
 propellers, 132, 133
 pumped blenders, 131, 132
 reservoirs, 102
 throttling valves, 131
 turbines, 132, 133
 valves, 131
 Mole, 546
 Molecular weight, 129
 Molecule, 440
 Monitoring
 algae in reservoirs, 101
 chlorination, 326
 coagulation, 138, 140
 control systems, 534
 disinfection, 328
 drinking water, 25, 27, 28
 filtration, 278, 282, 284, 294, 298, 303
 flocculation, 138, 140
 instrumentation, 28
 reservoirs, 101, 109, 117
 rivers, 497
 sedimentation, 244, 247
 taste and odor control, 497, 502
 Monochloramine, 339, 573
 Monomers, 129
 Monomictic, 75, 83
 Mosquitos, 109
 Most Probable Number (MPN) procedure,
 589, 594–607
 Motors, electric, 46
 Mouth-to-mouth resuscitation, 405
 MPN Index, 601, 605
 Mudballs, 270, 272, 280, 283, 294, 297,
 298, 304
 Multilevel intake-outlet structures, 79, 114
 Multi-media filter, 263, 268, 269
 Multiple Tube Fermentation Method (MPN
 Procedure), 589, 590, 594–607
 Municipal wastes, 495
 Musty tastes and odors, 81, 494, 497, 503, 527

N

National Pollutant Discharge Elimination
 System (NPDES) Permit, 27, 480,
 495
 Natural disasters, 35–36

- Nephelometer, 520, 562
 Nephelometric method, 562
 Nephelometric Turbidity Unit (NTU), 268, 562
 Nitrate, MCL (maximum contaminant level), 5
 Nitrification, 341, 342
 Nitrite-oxidizing bacteria, 342
 Nitrogen, Kjeldahl, 499
 Noble metal, 441
 Noncommunity water system, 6
 Nonionic polymer, 20, 129
 pretreatment process aids, 276
 Nonsettleable solids, 126
 Nontransient noncommunity water system, 6
 Normal conditions
 chlorination, 351, 364, 373
 coagulation-flocculation, 137
 filtration, 278, 281
 sedimentation, 244
 Notebooks, lab, 548
 NPDES Permit. *See* National Pollutant Discharge Elimination System (NPDES) Permit
 NTU. *See* Nephelometric Turbidity Unit (NTU)
 Nutrients
 reservoirs, 74, 77–78, 86, 92, 103, 105
 taste and odors, cause, 492, 497
- O**
- Objective, water treatment, 3, 25
 Observations, visual
 coagulation, 138, 155, 164
 corrosion, 453, 468, 472
 filtration, 284
 flocculation, 139, 155, 164
 odor control, 502–504
 plant tour, 11
 sedimentation, 245, 247
 taste and odor control, 502–504
 Occupational Safety and Health Act (OSHA), 550
 Occupational Safety and Health Administration (OSHA), 550
 Ocean, 60
 Odor, 7, 69, 83
 threshold, 7, 79, 516
 Ohm, 444
 Oil fields, 89
 Olfactory fatigue, 516
 Oligotrophic, 77
 Onsite chlorine generation, 337
 Open water, drowning prevention, 49
 Operation
 chlorination, 363–377
 chlorine dioxide, 393–396
 coagulation, 137–141, 170
 disinfection, 363–382
 filtration, 265, 278, 281, 284, 286, 296, 302–303
 flocculation, 137–141, 170
 intake structures, 119
 odor control, 516
 operator duties, 11
 particle counter, 310, 316–320
 records and reports, 39–41
 sedimentation, 219, 244, 252
 sludge handling, 240
 solids-contact units, 232
 Operator
 administration, 47
 certification, 44, 47, 52
 checklist, 11, 13
 daily procedures, 11–15
 duties, 51–52
 handling of chemicals, 19, 23
 maintenance, 38
 objectives, 25
 operation, 11–12
 pay, 52
 procedures, 11–15
 public relations, 49
 pumping rates, 12
 qualifications, 51
 recordkeeping, 11–15, 36–38
 requirements, 5
 responsibility, 19, 51
 safety, 401
 safety training programs, 405
 salary, 52
 sampling, 5, 27
 staffing needs, 52
 supervision, 47
 system pressures, 14
 training programs, 44–45, 528
 water quality, 14–15
 water quantity, 12–14
 Oral communications, 11, 15, 37, 164
 Orders (types of reservoirs), 107
 Organic
 chlorine demand, 74, 86, 338
 compounds, 537
 MCL (maximum contaminant level), 5–6
 source, 70
 substances, 489
 Organic loadings, reservoirs, 73, 82, 85
 Organic matter, chlorine demand, 330
 Organism, 588
 Orifices, flocculation, 133
 ORP probe. *See* Oxidation-reduction potential (ORP) probe
 Oscillatoria curviceps, 80
 OSHA. *See* Occupational Safety and Health Administration (OSHA)
 Outlet gates, 103, 112, 114. *See also* Intake structures
 Outlet structures. *See also* Intake structures
 cathodic protection, 118
 valves, 117
 Outlet zone, 210
 Overflow rate, 223
 Overgrazing, problems caused by, 89
 Overturn, lake, 62, 75, 77, 80, 84, 103
 Oxidation
 corrosion, 447
 disinfection, 83
 in distribution systems, 83
 taste and odor control, 509–512
 Oxidation-reduction potential (ORP)
 probe, 111, 400
 Oxidizing agent, 338
 Oxygen concentration cell, 450
 Oxygen depletion, 493
 Oxygen, dissolved. *See* Dissolved oxygen (DO)
 Oxygen, lack of, 50
 Ozonation, 512
 Ozone
 advantages, 422
 applications, 421
 characteristics, 20, 422
 chemical reaction, 421
 contactor, 420
 costs, 423
 description, 417
 disinfection, 332, 417
 effectiveness, 417, 422, 423
 electrical supply, 419
 equipment, 418
 gas preparation, 418
 generator, 419, 420
 limitations, 422–423
 maintenance, 421
 residual, 420
 safety, 421
 tastes and odors, 421, 509, 512
- P**
- Paddle flocculators, 131, 133
 Paddles, mixing, 132, 133
 Parasites, 326
 Particle counter
 bubbles, 317, 319
 cost, 314
 Cryptosporidium, 310, 312
 cumulative count, 312, 313
 differential count, 312, 313
 effluent turbidity, 316
 filter flow rate, 310
 filter ripening, 310
 filter run time, 310–311
 flow control, 317
 weir, 318
 Giardia, 309, 312
 grab samples, 313
 in-process measurements, 314
 in-process model, 313
 laboratory model, 313

- maintenance, 316–319
- membrane integrity, 317
- mounting diagram, 318
- need, 310
- operation, 310, 316–320
- overconcentration, 319
- performance monitoring, filter, 310
- portable, 313
- public health, 310
- quality assurance/quality control (QA/QC), 319–320
- references, 320
- sample tubing, 317
- sensitivity, 312
- startup, 319
- Surface Water Treatment Rule (SWTR), 308
- troubleshooting, 319
- turbidimeter, 315
- uses, 310
- Particle counting, 309. *See also* Particle counter
- Particulates, 126, 206
- Pathogenic organisms, 26, 326, 588
- Pathogen removal
 - coagulation, 330
 - disinfection, 330
 - filtration, 331
 - sedimentation, 331
- Pathogens, 588
- Pay, operator, 52
- Percent backwash water, 281, 291–293
- Percolation, 495
- Periphyton, 80
- Permeability, 265
- Permits
 - chemical application, 92
 - National Pollutant Discharge Elimination System (NPDES), 27, 480, 495
- Pesticides, 70, 89–90
- pH
 - algal blooms, 81
 - chlorination efficiency, 81, 329, 334, 346, 385
 - chlorine dioxide, 385
 - coagulation, 130
 - corrosion, 447, 451, 457
 - definition, 81
 - meter, 560
 - secondary maximum contaminant level (SMCL), 7
 - test, 559–561
- Phenol, 340, 510
- Phenolic compounds, 510
- Phenolic tastes and odors, 338, 340
- Phenol number, 514
- Phenolphthalein alkalinity, 568
- pH meter, 567
 - alternative indicators, 568
- Phosphate, 88, 448
- Photosynthesis, 81, 493
- Physical, disinfection, 331–332
- Physical, water quality, 5–6, 68–70
- Physiological response, chlorine, 402
- Phytoplankton, 78
- Piezometer, 280
- Pigtail tubing, 360, 363
- Pilot tests, 19
- Pink water, 510
- Pinpoint floc, 243
- Pipets, laboratory, 543
- Plankton, 80, 92, 491
 - sampling nets, 81
- Planning, maintenance, 38
- Plan review, chlorination, 389
- Plant process tests, 579–587
- Plan view
 - coagulation, 126, 128
 - definition, 126
 - flocculation, 126, 128
- Plastic tastes in water supply, 498
- Plate settlers, 213
- Platinum cobalt units, 181
- PLC. *See* Programmable logic controller (PLC)
- Plumbing, 498
- Pneumatic signal transmission, 29–30
- Points of chlorine application, 349, 351
- Point source, 204
- Polarization, 447
- Pollution, 492–493, 495
- Polyelectrolytes, 129
- Polymers
 - aging tanks, 159
 - approval for use, 130
 - coagulant, 128, 129, 130, 148
 - day tank, 159
 - dry, 159
 - feeder, 34
 - filter aid, 129
 - liquid, 159–160
 - preparation for solution, 158
 - pretreatment process aids, 276
 - safety, 159
 - selection, 129
 - solution, 158
 - types, 128, 129
 - use, 129
- Polyphosphate compounds, 448, 466
- Pond weeds, aquatic plants, 78
- Poppet valves, 365
- Population served, 328
- Pore size, filter, 260
- Postammoniation, 340
- Postchlorination, 9, 34, 346, 349, 350, 381
- Potable water, 96, 573
- Potassium permanganate, 20, 510, 522, 526
- Powdered activated carbon (PAC), 500, 511, 514–516, 526–527
- Power
 - factor, 46
 - failure, 34
 - management, 34–35, 46
- Preammoniation, 340
- Prechlorination, 9, 34, 336, 341, 346, 349, 350, 381, 509, 527
- Precipitation, 83, 204, 578
- Precoat, filtration, 262, 264
- Precursors, THM (trihalomethane), 74, 82, 349
- Prescriptive water rights, 66
- Presedimentation
 - coagulation, 204
 - debris dam, 204, 206
 - flocculation, 204
 - grit basins, 204, 206
 - sand traps, 204
 - troubleshooting, 249–250
- Presence-Absence Broth, 618
- Presence-Absence (P-A) method, 589, 591, 614–616
- Preservation of samples, 628
- Pressure filters, 263
- Pressures, distribution system, 16
- Presumptive test
 - example, 616
 - total coliform bacteria, 594
- Pretreatment, filtration, 275
- Prevention of accidents, 552
- Preventive maintenance, 38
- Primary regulations, 5
- Procedures
 - emergency, 32–36
 - operation, 11–15
 - sampling, 619
- Process actions
 - coagulation-flocculation, 138, 164
 - filtration, 280, 284, 296, 298
 - sedimentation, 245, 248
- Process, disinfection, 331
- Processing sludges, 27
- Process instrumentation and controls
 - cathode ray tube display, 31
 - computers, 31
 - control methods, 31
 - hybrid, 31
 - instrumentation, 28
 - microprocessors, 31
 - monitored functions, 28
 - relay logic, 30
 - sensing methods, 28
 - signal transmission, 29
 - valves, 29
- Process variables, 204
- Profile, reservoir
 - dissolved oxygen (DO), 76, 77
 - temperature, 76, 77
- Programmable logic controller (PLC), 409
- Program, maintenance, 38
- Propeller flocculators, 133–134
- Propellers, mixing, 133
- Protection from chlorine, 362
- Protective clothing, 551–552
- Public confidence, 488
- Public health, 3, 62, 65, 67

Public relations, 49, 488
 Public use, reservoirs, 72
 Public water system, 5
 Pumped blenders, 132
 Pumping rates, 12, 16

Q

Qualifications for operator jobs, 51
 Quality control, laboratory, 549
 Quality, drinking water, 12–15
 Quartz sleeve, 415
 Quicklime, 20, 461

R

Radioactivity, maximum contaminant level (MCL), 6
 Radiological water quality, 6, 68, 71
 Rapid mix, 34. *See also* Flash mixing
 Rapid sand filtration, 262
 Rate of chlorine withdrawal, 361, 390
 Rate of filtration, 265, 267, 286, 290, 297
 Rates, water, 2
 Raw water, 32, 499, 503
 Readycolt Coliforms 100 Presence-Absence Test, 589
 Reaeration-destratification, 102–109
 Reagent
 chlorine demand-free water, 585
 chlorine dosing solution, 585
 freshness, 580
 prepared, 575
 stock chlorine solution, 585
 using pipets, 544
 Rechlorination, 349
 Recirculation, solids-contact units, 231–234
 Reclaimed water, 64
 Recordkeeping
 algae control in reservoirs, 101
 coagulation, 162, 164, 166, 168, 170
 complaints, 523, 525
 corrosion control, 481
 filtration, 294, 295, 304
 flocculation, 162, 166, 168, 170
 intake structures, 120
 laboratory, 548
 reservoirs, 101, 111
 sedimentation, 246
 taste and odor control, 504, 517, 523, 524
 Records and reports
 accident, 37
 chemicals, 37
 complaints, 37, 523, 524
 daily operation, 11–15
 documenting daily operations, 37
 equipment, 37, 43
 historical, 16

inventory, 37
 laboratory, 39–41
 maintenance, 36–38
 management, 43
 operation, 36–38
 oral communications, 12, 14, 37
 performance, 37
 physical, 37
 plans and specifications, 37
 written documents, 37
 Recreation
 lakes, 119
 reservoirs, 72, 84, 86, 108
 Rectangular basins, 212
 Red alert, emergency, 32
 Reducing agents, 330, 335, 346, 584
 Reduction
 definition, 83
 stratified waters, 83
 References. *See also* Additional resources
 operation, 52
 particle counter, 320
 water treatment, 52
 Regeneration interval, granular activated carbon (GAC), 522
 Regulation of flows. *See* Flow regulation
 Regulations
 drinking water
 filtration, 307
 Giardia lamblia, 307
 Safe Drinking Water Act (SDWA), 5, 6, 326, 473
 watershed management, 88
 Relay logic, 31
 Removal of trees, 86
 Removal processes
 chlorine, 362
 pathogens, 330
 Removing chlorine, 362
 Repairs
 emergency, 38, 44
 maintenance, 38
 Reporting, disinfection, 327
 Reports. *See* Records and reports
 Representative sample, 169, 454, 619
 Reservoir management
 algae control, 92
 copper sulfate, 20, 92, 93, 491, 508
 importance, 72
 public use, 72
 purposes, 72, 86
 recreation, 72
 reduction of treatment costs, 85
 removal of trees, 86
 taste and odor control, 492, 503
 water quality, 72, 84, 86
 watershed management, 86
 Reservoirs
 additional resources, 71, 121
 algae, 92
 algal blooms, 92, 103, 105, 111, 118

anaerobic, 103
 blue-green algae, 80, 96, 103
 cattails, 109
 chlorination, 349
 control of algae, 92
 destratification, reaeration, 102–109
 disinfection, 349
 dissolved oxygen depletion, 92, 108
 draining, 108–109
 flood gates, 108
 freezing, 102–103, 106, 116
 hypolimnion, 104, 105
 inlet-outlet structures, 112–116 (*see also* Intake structures)
 inspection, 108
 intake structures, 107, 112–117 (*see also* Intake screens; Intake structures; Outlet structures)
 maintenance, 108
 math assignment, 121
 mixing, 103
 monitoring, 109, 117
 mosquitos, 109
 nutrients, 103, 105
 orders (types), 107
 outlet gates, 103 (*see also* Outlet structures)
 reaeration, 102–109
 recordkeeping, 111
 recreation, 72, 84, 85, 108
 safety, 112
 sampling, 619
 service storage, 16, 72
 silt survey, 107
 source of water, 62
 stratification, 62, 75, 102–109, 499
 taste and odor problems, 103, 108, 111, 117
 thermal stratification, 75, 102–109
 turnover, 103, 107
 vegetation, 109
 water quality, 72, 79, 84, 102, 107, 109, 110, 111, 113, 116
 withdrawal level, 115
 Residual analyzer, chlorine, 377, 399
 Residual chlorine, 331, 334, 339, 342, 344, 346, 377, 399, 572, 584
 concentrations, 578
 types, 573
 Respiration, algae, 81, 493
 Resuscitation, cardiopulmonary
 resuscitation (CPR), 24
 Rights to use water, types, 66
 Riparian water rights, 66
 Ripening period, filtration, 276, 282
 Rivers, 61
 Rotameter, 356
 Rotten egg tastes and odors, 503
 Routine maintenance, 42
 Runoff, surface, 73, 495, 496
 Run time, filtration, 281, 297, 298
 Ryznar Index (RI), 459

S

- Sacrificial anode, 441
- Safe Drinking Water Act (SDWA), 5, 305–306, 326, 442, 473
- Safe drinking water laws, 5–6, 326
- Safety. *See also* Laboratory safety
 - algae control in reservoirs, 92, 101
 - buddy system, 50, 305
 - causes of accidents, 49
 - chemical applications, 101
 - chemicals, 22, 51
 - chlorination, 360, 361, 401–406
 - chlorine dioxide, 385, 405
 - coagulation, 159, 163, 168, 170, 178
 - confined spaces, 50
 - drinking water, 326
 - drowning prevention, 49
 - electrical equipment, 50
 - explosive atmospheres, 49
 - filtration, 305
 - fire blanket, 555
 - fire extinguisher, 556
 - flocculation, 163, 168, 170, 178
 - General Industry Safety Orders, 550
 - hazards, 42, 401
 - hypochlorite, 405
 - intake structures, 120
 - mechanical equipment, 50
 - open surfaces, 50
 - oxygen, 50
 - ozone, 421
 - procedures, 49
 - program, 49
 - pump stations, 51
 - reservoirs, 112
 - sedimentation, 244
 - taste and odor control, 512, 521
 - toxic gases, 50
 - ultraviolet (UV) systems, 408
 - underground structures, 50
 - ventilation, 51
 - waste disposal, 555
- Safety Data Sheet (SDS), 19, 393, 552
- Safe yield for surface water supplies, 67
- Salary, operator, 52
- Sample preservation, 627, 628
- Sample, unchlorinated, filtering, 608
- Sampling
 - additional resources, 627
 - automatic, 624
 - bacteria quantity, 596
 - chain-of-custody protocol, 627
 - chlorination, 327, 328
 - coagulation, 168
 - collection, 624–628
 - composite samples, 25, 619, 623
 - containers, 627, 628
 - depth, 624–626
 - depth sampling, 625
 - devices, 624
 - disinfection, 327, 328
 - distribution system, 620–622
 - drawn from main, 621
 - drinking water, 3, 619–628
 - errors, 619
 - filtration, 284, 287
 - first-draw sampling, 627
 - flocculation, 169
 - formulas, 621
 - grab samples, 25, 623, 625
 - groundwater, 620
 - holding time, 627, 628
 - in-plant, 620
 - Kemmerer depth sampler, 626
 - labeling container, 627
 - lakes, 620
 - manual, 624
 - odor control, 499, 504, 525
 - parameters, 623
 - preservation, 627, 628
 - preservation of sample, 628
 - procedures, 619
 - reference-type sample, 549
 - reporting lab results, 627
 - representative sample, 619
 - reservoirs, 620
 - results, 619
 - rivers, 619
 - sedimentation, 251
 - small water system, 621
 - source water, 619
 - stations, 624
 - surface, 625
 - taste and odor control, 499, 504, 526
 - techniques, 625–627
 - types, 619, 623–624
 - volume, 628
 - water tap, 626
 - well profile, 620
- Sampling bottles, 592
- Sanitary landfills, 3
- Sanitary survey, 499
 - groundwater, 66
 - surface water, 67
 - treatment of water, 67
- Saturation, 456
- Scheduling maintenance, 38
- Screens, intake, 106, 112–117
- SDWA. *See* Amendments to the Safe Drinking Water Act (SDWA)
- Seawater intrusion, 3, 61, 64
- Secchi disc, 103
- Secondary regulations, 7
- Security, plant, 45
- Sedges, aquatic plants, 78
- Sedimentation
 - abnormal conditions, 248
 - additional resources, 255
 - administration, 246
 - baffles, 207, 209
 - basins, 208–219
 - cathodic protection, 234, 469
 - circular basins, 213, 214
 - clarifiers, 213–215, 228, 229, 467
 - compression settling, 209
 - control, process, 245
 - corrosion control, 234, 253
 - currents, 207, 208
 - debris dam, 204, 206
 - definition, 204
 - density, 206
 - density currents, 207, 208, 245
 - description, 204
 - design, 208
 - detention time, 219–223, 234
 - double-deck basins, 213
 - eddy currents, 207
 - effective water depth, 225
 - efficiency, 204, 245
 - electrical charge, 207
 - emergency, 34
 - equipment, 252
 - floc characteristics, 206
 - flow diagram, 205
 - formulas, 220, 234
 - grit basins, 204, 206
 - high-rate settlers, 213, 217
 - hydraulics, 207
 - inlet zone, 208
 - interaction with other processes, 243
 - laboratory, 251
 - launders, 210
 - maintenance, 252–253
 - math assignment, 255
 - mean flow velocity, 225
 - monitoring, 244, 247
 - normal conditions, 244
 - operation, 219, 244, 252
 - outlet zone, 210
 - overflow rate, 223
 - particle, 204
 - pathogen removal, 330
 - performance, 212, 245
 - pinpoint floc, 243
 - plate settlers, 213
 - presedimentation, 20, 204
 - process actions, 138, 248
 - process variables, 204
 - purpose, 8, 204
 - recordkeeping, 246
 - rectangular basins, 213
 - safety, 254
 - sampling, 251
 - settling rate, particles, 207, 224
 - settling zone, 208
 - short-circuiting, 208, 213, 245
 - shutdown, 250, 251
 - size of particles, 204, 206
 - sludge blanket, 215, 216, 231, 245
 - sludge removal, 210, 211, 220, 240–243, 246, 497, 502
 - sludge solids, 246
 - sludge zone, 209
 - solids-contact units, 215, 227–243

Sedimentation (*continued*)

square basin, 213, 215
 startup, 250
 surface loading, 223
 taste and odor control, 505, 527
 temperature, 206, 207, 216, 249
 troubleshooting, 249
 tube settlers, 213, 217
 turbidity, 243, 251
 types of basins, 212
 upflow clarifiers, 215
 variables, 204
 viscosity, 204
 visual observations, 245, 247
 v-notch weirs, 210
 water quality, 243, 247, 248, 249
 weir loading rate, 226
 weirs, 210
 wind, 207, 208, 215
 zones, 208

Selenium, 5

Self-contained breathing apparatus, 362, 386, 401, 402

Sensing (measuring) methods, 28

Sensitivity, particle counter, 312

Septic sludge, 240

Septic tank leaching systems, 3, 87, 495

Septic tastes and odors, 494, 497

Septum, 264

Service storage reservoirs, 16

Settleable solids, 126

Settling rate, particles, 207, 224

Settling zone, 208

Shock, electric, 550, 552

Shock load, 212

Shortage, water, 2

Short-circuiting

- detention time, 219
- flocculation, 134, 139
- in reservoirs, 67
- sedimentation, 208, 213, 245

Shortened filter runs, 81, 298

Shutdown

- chlorination, 364
- chlorine dioxide, 394
- coagulation-flocculation, 166
- filtration, 300, 303
- sedimentation, 248, 250
- ultraviolet (UV) systems, 412

Signal transmission

- electrical, 30
- electronic, 30
- hydraulic, 30
- mechanical, 29
- pneumatic, 29

Silica, 448, 466

Silt

- loading, 85
- source, 60
- survey, reservoir, 107

Silver, 7

Single-level intake structures, 113, 114

Sinkholes, 108

Size of particles, 204, 206

Skin burns, first aid, 24

Slake, 461

Slow sand filtration, 264

Sludge

- blanket, 215, 216, 231, 245
- control, 231
- definition, 150
- floc, 150
- handling and disposal
 - alum sludges, 239
 - blanket sounder, 242
 - characteristics, 240
 - discharge standards, 27
 - disposal, 27
 - drag-chains, 211, 240, 241
 - equipment, 240, 241, 252
 - flights, 240, 241
 - frequency of removal, 240, 242
 - manual sludge removal, 240
 - mechanical rakes, 240, 241
 - mechanical sludge removal, 240, 241, 247
- National Pollutant Discharge Elimination System (NPDES) Permit, 27
- need, 497, 503
- operation, 242
- processing, 26, 27
- removal, 240, 241
- sedimentation, 10
- septic sludge, 240
- sounder, sludge depth, 242
- sources, 26
- traveling bridges, 240, 241

lagoons, 494

removal, 210, 211, 220, 240–243, 246, 497, 503

solids, 246

taste and odor control, 498, 503

zone, 209

Slurry, 229–231, 233, 264, 461, 515

Small water system sampling, 621

Snowmelt, 73

Soda ash, 20, 461, 462

Sodium carbonate, 20

Sodium chlorite, 392

Sodium fluoride, 20

Sodium hydroxide, 20, 551

Sodium hypochlorite, 20, 336

Sodium silicofluoride, 20

Softening

- chemicals, 19, 20
- purpose, 10
- solids-contact units, 227

Soil grading, 89

Soils, corrosion, 438, 439, 443, 444, 469

Solids-contact units

- advantages, 228
- algae problems, 230
- alkalinity, 231

arithmetic, 234

cathodic protection, 234

chemical dosage, 231–242

coagulation, 227

corrosion, 234

description, 215, 216, 227

detention time, 234

disadvantage, 228

drawings, 228, 229

flocculation, 135, 227

flow rate, 230

formulas, 234, 235

lime dose, 235

maintenance, 234

operation, 231

operational control, 231

overflow rate, 223

recirculation rate, 231, 233, 234

sampling taps, 230

sedimentation, 227

sludge blanket, 215, 231, 245

sludge control, 231

slurry, 229, 231–234

softening, 227

taste and odor problems, 230

temperature, 216, 230, 231

troubleshooting, 249

turbidity, 227, 231

volume over volume test, 232

water quality, 233, 249

weighting agents, 231, 233

wind, 215

Solution feeders, 351–353, 365

Solutions, chemical, 545–548

Sounder, sludge, depth, 242

Source, particulates, 126

Sources of water

- contamination, 68
- direct runoff, 60
- groundwater, 61, 63
- hydrologic cycle, 61
- lakes, 62
- ocean, 60
- reclaimed water, 64
- reservoirs, 62
- rivers, 61
- selection of source, 65
- springs, 61, 64
- streams, 61
- surface water, 60
- water cycle, 61
- wells, 64

Source water

- additional resources, 121
- math assignment, 121
- sampling, 619

Spare parts, managing, 43

Species, algae, 94

Specifications, review, chlorination, 389

Specific gravity, 152, 580

Spills, chemical, 51, 496

Spore-forming bacteria, 330

- Springs, sources of water, 64
 - Square basin, 213, 215
 - Staffing needs, operators, 51
 - Stage 2 Disinfection By-Products (Stage 2 D/DBP), 329
 - Standardization, 545
 - Standardized lab solutions, 566
 - Standards, microbial, 7, 328
 - Standard solution, 545
 - Startup
 - chlorination, 364, 369
 - chlorine dioxide, 395
 - coagulation, 167
 - disinfection, 364, 369
 - filtration, 300, 302
 - flocculation, 166
 - particle counter, 319
 - sedimentation, 250
 - ultraviolet (UV) systems, 412
 - Station, sampling, 624
 - Steel, corrosion, 470
 - Steel specimen coupons, 453
 - Sterilization, 326, 592
 - Stirrers, flocculation, 133
 - Stock solution
 - concentrations, 580
 - creating, 580
 - volume calculation, 580
 - Stock solution, preparing, 593
 - Storage
 - chemicals, 21, 552
 - chlorine containers, 373, 386
 - flow regulation, 15
 - Stormwater runoff, 91, 495
 - Strategy, taste and odor control, 518, 525
 - Stratification, reservoirs, 62, 75, 102–106, 499
 - Stray current electrolysis, 443, 470
 - Streaming current meter, 155
 - Streams, 61
 - Streicher backwash design, 274
 - Strip charts, electronic instrumentation, 30
 - Submergence, 273
 - Subsidence, land, 64
 - Sulfate-reducing bacteria, corrosion, 449
 - Sulfate, secondary maximum contaminant level (SMCL), 7
 - Superchlorination, 509
 - Supernatant, 518, 582
 - Supersaturation, 456, 459, 463
 - Supersaturation, dissolved oxygen (DO), 82, 493
 - Surface loading, 223
 - Surface runoff, 495, 496
 - Surface wash, filters, 271, 272, 297, 299, 302, 303
 - Surface water sampling, 582
 - Surface Water Treatment Rule (SWTR), 64, 70, 289, 291, 307, 308, 327, 346
 - Suspended solids, 126
 - Sustained yield for wells, 64
 - Swallowing or inhalation, first aid, 24
 - Swampy tastes and odors, 503
 - SWTR. *See* Surface Water Treatment Rule (SWTR)
 - System demands, 16
- ## T
- Tanks, chlorine, 351, 361–363, 387
 - Tapered-energy mixing, 135
 - Taste and odor control (T&O)
 - Actinomycetes, 490
 - activated carbon, 511, 514–522, 527
 - additional resources, 528
 - adsorption, 514, 522
 - aeration, 506–508
 - agricultural wastes, 496
 - air blowers, 506
 - air stripping, 508
 - algae, 79, 490
 - algal bloom, 491, 492, 505, 527
 - backflow prevention, 501
 - biological growths, 490, 500, 503
 - bitter tastes, 332, 503
 - blowers, 506
 - cascade aerators, 507
 - causes, 489–494
 - chemicals, 20
 - chemical spills, 496
 - chlorine, 9, 79, 339, 349, 381, 509
 - chlorine dioxide, 339, 513
 - chlorophenolic, 510
 - coagulation, 505
 - complaints, 488, 523, 524, 525
 - compounds, 489
 - conditions, waterworks facilities, 497
 - consumer complaints, 488, 523, 524, 525
 - copper sulfate, 92, 93, 491, 508
 - cross-connections, 499, 501
 - dairies, 497
 - dead ends, 498, 501
 - decant water, 494
 - degasification, 505, 507
 - die-offs, 491, 494
 - disinfection, 10, 79
 - distribution systems, 497, 500, 503
 - dosages, 527
 - earthy tastes, 81, 494, 503, 527
 - effects of problems, 488
 - empty bed contact time (EBCT), 522
 - environmental conditions, 492
 - eutrophication, 492
 - feedlots, 497
 - fertilizers, 496
 - fish kills, 494
 - fishy tastes, 503, 509
 - flocculation, 505, 527
 - flushing, 498
 - formulas, 518
 - geosmin, 81, 489, 527
 - granular activated carbon (GAC), 522
 - grassy tastes, 79, 503, 509
 - household plumbing, 498
 - human causes, 495
 - hydrogen sulfide, 503
 - identifying problems, 523
 - industrial discharges, 495
 - inspection, 498, 500
 - irrigation runoff, 495, 496
 - jar test, 505, 510, 516, 517, 518
 - laboratory, 526
 - lagoons, sludge, 494
 - locating sources, 498
 - maintenance, 503, 518
 - math assignment, 528
 - methylisoborneol (MIB), 81, 489, 527
 - microbial populations, 491, 492
 - monitoring program, 502
 - monitoring, rivers, 497
 - municipal wastes, 495
 - musty tastes, 81, 494, 497, 503, 527
 - National Pollutant Discharge Elimination System Permit (NPDES), 497
 - nutrients, 492, 497
 - odor, secondary maximum contaminant level (SMCL), 7
 - oxidation, 509–513
 - oxygen depletion, 493
 - ozone, 420, 509, 512
 - permit, National Pollutant Discharge Elimination System (NPDES), 497
 - phenolic compounds, 510
 - photosynthesis, 493
 - plankton, 491
 - plant inspection, 498
 - plastic tastes, 498
 - plumbing, household, 498
 - pollution, 492, 495
 - potassium permanganate, 510, 522, 527
 - powdered activated carbon (PAC), 511, 514–516, 527
 - prechlorination, 509, 527
 - prevention, 502, 528
 - problem identification, 523
 - raw water, 499, 502
 - recordkeeping, 504, 523, 524
 - recycle water, 494
 - regeneration interval, granular activated carbon (GAC), 522
 - removal by filtration, 274
 - reservoirs, 79, 82, 92, 103, 111, 115, 492, 499
 - rotten egg tastes, 503
 - runoff, 494, 496
 - safety, 511
 - sampling, 499, 504, 526
 - sanitary survey, 499
 - sedimentation, 505, 527
 - septic, 494, 498
 - sludge lagoons, 494
 - sludge removal, 497, 503
 - solids-contact units, 230
 - sources, 495
 - spills, 496
 - stormwater runoff, 495

- Taste and odor control (T&O) (*continued*)
 strategy, 516, 526
 stratification, 499
 sulfate-reducing bacteria, 491
 swampy, 503
 taste tests, 499, 502, 525
 taste threshold test, 499, 502
 temperature, 493
 threshold odor number (TON), 79, 516
 training, operator, 528
 transmission systems, 499, 526
 treatment methods, 505
 treatment plants, 497, 500
 urban runoff, 496
 visual observations, 499
 wastewaters, 495
 waterfall devices, 507
 water quality, 70
 waterworks facilities, 498–502
- Taste tests, 498, 502, 523
- TCE. *See* Tichloroethylene (TCE)
- TDS. *See* Total dissolved solids (TDS)
- Techniques, laboratory, 553. *See also*
 Laboratory procedures
- Temperature
 chlorination, 329, 346
 corrosion, 445
 disinfection, 329, 346
 flocculation, 140
 profile, 76, 77
 sedimentation, 204, 206, 249
 solids-contact units, 216, 228, 231
 tastes and odors, 492–494
- Temperature test, laboratory, 557
- Tests
 biological test goals, 589
 culturing media, 590
 enzyme substrate coliform test, 591
 goals, 589
 lab methods, 618
 overview, 589–592
 membrane filter, 591
 Membrane Filter Method-*E. coli* (EPA Method), 591–592
 Multiple Tube Fermentation Method (MPN Procedure), 590
 Presence-Absence (P-A) Method, 591
 total coliform bacteria, 594–618
- Tests for plant processes, 579–588
- Test tubes, 539
- Thermal stratification
 dimictic, 75, 83
 monomictic, 75, 83
 reduction, 83
 reservoirs, 75, 102–109
 temperature profile, 76, 77
- Thermocline, 75
- Thermometer types, 557
- THMs. *See* Trihalomethanes (THMs)
- Threshold odor, 7, 79, 516
- Threshold odor number (TON), 502
- Throttling valves, 131
- Time, detention
 chlorine, 345
 coagulation, 128, 141, 142
 curves, 144, 145, 345
 definition, 141
 flocculation, 133, 141, 142
 reservoirs, 67
 sedimentation basins, 219–223, 234
 solids-contact units, 234
- Time of filtration, 81, 281, 297, 298
- Titrate, 455
- Titration, 545, 564–579
- T&O. *See* Taste and odor control (T&O)
- TOC. *See* Total organic carbon (TOC)
- TON. *See* Threshold odor number (TON)
- Ton tanks, chlorine, 361–362
- Tools, 42
- Topography, 63, 87
- Total alkalinity, 568
- Total coliform bacteria, 589
 test procedures, 594–618
- Total Coliform Rule, 588
- Total coliform test, 589
- Total dissolved solids (TDS), 7, 458
- Total organic carbon (TOC), 179
- Total suspended solids (TSS), 409
- Toxic fumes, 555
- Toxic gases, 50
- Toxic materials, 555
 used in laboratories, 551
- Toxic metals, 70, 448, 455
- Training programs
 operator, 44, 528
 operator safety, 405
- Transient noncommunity
 water system, 7
- Transmission systems, water, 499, 526
- Transpiration, 63
- Traveling bridge, 210, 240, 241
- Traveling screens, 117
- Treatment processes
 chlorination, 9, 10
 coagulation, 9, 126
 disinfection, 10
 emergency, 32
 filtration, 8
 flash mixing, 9
 flocculation, 127
 flow regulation, 15
 odor control, 504
 purpose, 8
 reclaimed water, 65
 sedimentation, 204
 solids-contact units, 227
 summary table, 4
 taste and odor control, 504
- Tree removal, 86
- Trichloramine, 339, 573
- Trichloroethylene (TCE), 2
- Trihalomethanes (THMs), 4, 9, 75, 82, 136,
 179, 307, 330, 331, 349, 391, 512,
 573
- Trimetaphosphate, 464
- Troubleshooting
 ballasted flocculation, 194
 chlorination, 380, 384, 385, 399
 chlorine dioxide, 397, 398
 coagulation, 165, 182
 corrosion, 472
 disinfection, 380, 384, 385, 398
 filtration, 380
 flocculation, 165
 particle counter, 319
 sedimentation, 250
 solids-contact units, 250
- Trout, 85
- True color, 180
- Trunnions, 361
- TSS. *See* Total suspended solids (TSS)
- Tuberculation, 438
- Tubercule, 440, 451
- Tube settlers, 213, 217
- Tubes, test, 539
- Tules, aquatic plants, 78
- Turbidimeter, 137, 279, 280, 294, 303, 315,
 563
- Turbidity
 breakthrough, 32, 35, 266, 270, 281, 296,
 297, 298
 cause, 69
 chemicals, 19
 chlorination, 330, 346
 chlorine demand, 74
versus color, 561
 disinfection, 329, 346
 erosion, 88
 filtration, 281, 284, 296, 297, 298, 303,
 308
 measurement, 562
 meter, 562
 reading, 564
 removal, 25, 129, 139, 163, 164
 reservoirs, 73, 85
 sedimentation, 244, 251
 solids-contact units, 227, 231
 source, 69
 SWTR compliance, 308
 test, 561
 units (TU), 227, 243, 541, 563
 and measures, 562
- Turbine flocculators, 133
- Turbines, mixing, 132, 133
- Turnover, lake, 62, 75, 77, 80, 83, 102
- Typhoid, contamination of water supply,
 62
- ## U
- UFRV. *See* Unit filter run volume (UFRV)
- Ultrasonic waves, 332
- Ultraviolet (UV) systems
 alarms, 414
 description, 406

disinfection, 332, 406, 407, 408, 409, 411, 414
 dosage, 410
 equipment, 408
 fouling, quartz sleeve, 415
 maintenance, 415, 416
 operation, 409
 safety, 408
 shutdown, 412, 413
 sleeve cleaning, 415
 startup, 412
 troubleshooting, 417
 types, 407
 Unchlorinated samples, filtering, 608
 Underdrains, 263, 268, 281, 297, 298, 299, 304, 311
 Underground structures, safety, 50
 Uniformity coefficient, 266
 Unit filter run volume (UFRV), 281, 288, 290, 294, 730, 731, 746, 747
 Upflow clarifiers. *See* Solids-contact units
 Urban runoff, 496
 UV lamps, 407, 408, 409, 411, 415, 416, 417
 UV systems. *See* Ultraviolet (UV) systems

V

Vacuum-controlled chlorinator, 353–359, 377
 Vacuum sweep, 210
 Valves
 butterfly, 117
 chlorination, 363, 365, 368, 369, 375
 controls, 29
 intake, 113
 mixing, 131
 outlet, 113, 117
 Variables
 chlorination, 179
 corrosion, 443
 sedimentation, 204
 Vegetation, reservoir, 109
 Velocity, water, corrosion, 445
 Ventilation
 chlorine rooms, 389
 energy conservation, 45
 safety, 50
 Vertical flocculators, 133
 Viruses, 327, 330, 391
 Viscosity, 206, 207
 Visual observations
 coagulation, 139, 155, 164
 corrosion, 453, 468, 472
 filtration, 284
 flocculation, 139, 155, 164
 plant tour, 12
 sedimentation, 245, 247
 taste and odor control, 499
 V-notch weirs, 210
 Volatile, 506
 liquids, 552
 Voltage, 467
 Volume of sample, 628
 Volume over volume test, 232

W

Wash water, filter, 300, 301
 Waste, disposal of lab waste, 555
 Wastewater
 facilities, 62, 67
 odors, 495
 sources, 87
 tastes, 495
 Water
 acid rain, 2
 conservation, 2
 contamination, 2
 costs, 2, 3
 cycle, 60, 61
 evaporation, 60
 groundwater, 61, 63
 hydrologic cycle, 61
 irrigation runoff, 2
 limited resource, 2
 presence, 2
 rates, 2
 sampling, 619
 seawater intrusion, 61, 64
 affects, 3
 shortages, 2
 sources, 4
 surface, 60
 testing procedures, 589
 treatment, 3, 4
 water quality problems, 86
 Waterborne diseases, 326
 Water chemistry, typical units, 545
 Waterfall devices, 507
 Water hyacinths, aquatic plants, 78
 Water quality
 additional resources, 26
 biological, 68, 70
 chemical, 68, 69
 coagulation, 138, 140, 162, 164, 165, 169
 color, 69
 complaints, 26
 consumer demands, 3
 drinking water, 12–15
 filtration, 278, 280, 281, 284, 294, 303
 flocculation, 138, 140, 162, 164, 165, 169
 indicators, 619, 623, 626, 627
 inorganic, 69
 odor, 69
 organic, 70
 physical, 7, 62, 68
 problems, 87
 radiological, 6, 68, 71
 reservoirs, 72–79, 84, 102, 107, 109, 111, 114, 115
 sedimentation, 243, 247, 248, 249
 solids-contact units, 253
 taste, 69
 temperature, 69
 tests, 557–618
 turbidity, 69
 Water quantity, treated, 12–15
 Water rates, 2
 Water rights, basic types and acquisition, 66
 Watershed conditions, 73. *See also* Watershed management
 Watershed management
 costs, 87
 farming practices affect on watershed, 89
 fertilization, 88
 fires, 90
 herbicides, 89
 industrial discharges, 88
 land use, 90
 livestock grazing, 89
 need, 87
 pesticides, 89
 regulations, 87, 88
 soil grading, 89
 stormwater runoff, 91
 waste water, 87
 water quality problems, 87
 wildfires, 90
 Water supply systems
 chlorination equipment, 361
 chlorination of, 349
 Water table, 61, 63, 64, 66
 Water tap sampling, 626
 Water treatment plants
 appearance, 49
 complete treatment, 72
 costs, 2, 3, 81, 82, 84, 87
 direct filtration, 72
 flow diagram, 9
 inspection, 500
 objectives, 3, 25
 purpose, 51
 records, 46
 water quality problems, 2
 Weather, water demands affected by, 16
 Weeds, pond, aquatic plants, 78
 Weep holes, 108
 Weighing, chlorine, 390
 Weighting agents, 231, 233
 Weirs
 flocculation, 133
 laundering, 155, 210
 loading rate, 226
 sedimentation, 210
 Wells
 chlorination, 349
 construction, 67
 drawdown, 67
 sampling, 620
 source of water, 64
 Wet chemistry, 170

Wildfires, 73, 90

Wind, effect on sedimentation, 207, 208,
215

Withdrawal level, reservoirs, 116

Withdrawal rate, chlorine, 390

Work order, 44

Worksheets, laboratory, 548

Wrench, chlorine, 363

Y

Yield

safe, surface water
supplies, 68

sustained, wells, 64

Yoke-type connectors,
362

Z

Zinc coatings, 466

Zinc, secondary maximum contaminant
level (SMCL), 7

Zone of saturation, 61, 63

Zones, sedimentation basins, 208

Zooplankton, 78